

**TESTING FOR THE VERIFICATION OF COMPLIANCE OF
MICROINVERTER WITH:
EN 50549-1: 2019:
REQUIREMENTS FOR GENERATING PLANTS TO BE
CONNECTED IN PARALLEL WITH DISTRIBUTION
NETWORKS - PART 1: CONNECTION TO A LV DISTRIBUTION
NETWORK - GENERATING PLANTS UP TO AND INCLUDING
TYPE B**

(REQUIREMENTS FOR PLANTS TYPE B)

Test Report Number: SUEE240500006451
Type: Microinverter
Tested Mark: **ABSAAR**[®]
Trade Models: AB800A
Variant Models: AB400A, AB600A

APPLICANT

Name.....: D&W The Motion Corporation GmbH&Co.KG
Address: Dückerweg 21, 44867 Bochum, Germany

TESTING LABORATORY

Name.....: **SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch**
Address: 1/F., Building 12, Xinxing Industry Park, No.78, Xinglin Street, Suzhou Industrial Park, Suzhou, Jiangsu, China

Conducted (tested) by: Horace Hao
(Project Engineer)

Approved by: Colin Chen
(Technical Reviewer)

Date of issue: 2024/05/30

Number of pages: 148

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Important Note:

- This document is issued by the Company under its General Conditions of service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes. The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

Data Provided By The Client:

The following data has been provided by the applicant:

1. Any information regarding technical characteristics of the equipment (ratings, operation modes, software and hardware versions, dimensions and weight).
2. Equipment operation & construction information (manuals, electrical diagrams, information about components, operation procedures).
3. Documental information (brand and models names, address or other information about applicant, company or manufacturer).
4. Other information remarked within this report.

SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch declines any responsibility with respect to the information provided by the applicant and that it may affect to the validity of results. It is not covered by A2LA accreditation.

Test Report Historical Revision:

| Test Report Version | Date | Resume |
|---------------------|------------|---|
| SUEE240500006451 | 2024/05/30 | <p>First issuance.</p> <p>Remarks: According to the declaration from the applicant, the only difference between the EUT (test samples in this report) and testing sample of report SUEE240400004851, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch as below: -Update applicant, manufacturer, trademark, models name, label, appearance and equipment type ect.</p> <p>After evaluation, no clause needs to retest. All test data originate from the report SUEE240400004851, SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch.</p> |

INDEX

| | | |
|-----------|--|------------|
| 1. | SCOPE | 4 |
| 2. | GENERAL INFORMATION..... | 5 |
| 2.1. | Testing Period and Climatic conditions..... | 5 |
| 2.2. | Equipment under Testing..... | 5 |
| 2.3. | Reference Values..... | 9 |
| 2.4. | Test equipment list..... | 10 |
| 2.5. | Measurement Uncertainty..... | 10 |
| 2.6. | Test set up of the different standard..... | 11 |
| 2.7. | Factory Information..... | 11 |
| 2.8. | Definitions..... | 12 |
| 3. | RESUME OF TEST RESULTS..... | 13 |
| 4. | TEST RESULTS | 15 |
| 4.1. | Normal operating range..... | 15 |
| 4.1.1. | Operating frequency range..... | 15 |
| 4.1.2. | Minimal requirement for active power delivery at underfrequency..... | 19 |
| 4.1.3. | Continuous operating voltage range..... | 21 |
| 4.2. | Immunity to disturbances..... | 22 |
| 4.2.1. | Rate of change of frequency (ROCOF) immunity..... | 22 |
| 4.2.2. | Under-voltage ride through (UVRT)..... | 23 |
| 4.2.3. | Over-voltage ride through (OVRT)..... | 45 |
| 4.3. | Active response to frequency deviation..... | 64 |
| 4.3.1. | Power response to overfrequency..... | 64 |
| 4.3.2. | Power response to underfrequency..... | 69 |
| 4.4. | Power response to voltage changes..... | 70 |
| 4.4.1. | Setpoint control modes..... | 70 |
| 4.4.2. | Voltage related control mode..... | 81 |
| 4.4.3. | Voltage related active power reduction (Volt-Watt)..... | 92 |
| 4.4.4. | Short circuit current requirements on generating plants..... | 95 |
| 4.5. | EMC and power quality..... | 96 |
| 4.5.1. | Harmonic emissions..... | 97 |
| 4.5.2. | Flicker and voltage fluctuations..... | 99 |
| 4.6. | Interface protection..... | 102 |
| 4.6.1. | Requirements on voltage and frequency protection..... | 102 |
| 4.6.2. | Means to detect island situation..... | 133 |
| 4.6.3. | Digital input to the interface protection..... | 137 |
| 4.7. | Connection and starting to generate electrical power..... | 137 |
| 4.7.1. | Automatic reconnection after tripping..... | 137 |
| 4.7.2. | Starting to generate electrical power..... | 138 |
| 4.7.3. | Synchronization..... | 141 |
| 4.8. | Ceasing and reduction of active power on set point..... | 141 |
| 4.8.1. | Ceasing active power..... | 141 |
| 4.8.2. | Reduction of active power on set point..... | 142 |
| 4.9. | Requirements regarding single fault tolerance of interface protection system and interface switch..... | 143 |
| 5. | PICTURES..... | 144 |
| 6. | ELECTRICAL SCHEME | 148 |

1. SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Suzhou Branch has been contracted by D&W The Motion Corporation GmbH&Co.KG, in order to perform the testing according to the EN 50549 – 1: 2019: Requirements for generating plants to be connected in parallel with distribution networks - part 1: connection to a LV distribution network - generating plants up to and including type B.

The tests offered at this test report evaluate the EUT compliance with the requirements of **Type B**.

2. GENERAL INFORMATION

2.1. TESTING PERIOD AND CLIMATIC CONDITIONS

The necessary testing has been performed between November 16th of 2023, February 17th and April 10th of 2024.

All the tests and checks have been performed at climatic conditions:

| | |
|-------------------|-------------|
| Temperature | 25 ± 5 °C |
| Relative Humidity | 50 ± 10 % |
| Pressure | 96 ± 10 kPa |

2.2. EQUIPMENT UNDER TESTING

Apparatus type : Microinverter
 Installation : Fixed installation
 Manufacturer : D&W The Motion Corporation GmbH&Co.KG
 Trade mark : **ABSAAR**[®]
 Model / Type reference : AB800A
 Serial Number : WWA2344068
 Software Version : DH01.001-000-000
 Rated Characteristics : DC Input: MPPT 33~55 Vdc (60 Vdc max.),
 14 A*2 Maximum.
 AC Output: 230 Vac, 50 Hz, 3.48 A, 800 W.























Date of manufacturing: 2023

Test item particulars

Input : DC
 Output : AC, L/N/PE
 Class of protection against electric shock... : Class I
 Degree of protection against moisture : IP67
 Type of connection to the main supply : Single phase – Fixed installation
 Cooling group : Natural Cooling
 Modular : No
 Internal Transformer : Yes

Copy of marking plate (representative):

| Microinverter Model:AB800A | | ABSARR OVER 40 YEARS OF GERMAN TECHNOLOGY | |
|-------------------------------------|-----------|---|-----------------|
| PV Max. Input Voltage : | 60Vdc | Rated Output Power : | 800W |
| Full load MPPT Voltage : | 33~55Vdc | Rated Output Current : | 3.48A |
| Operating Voltage Range : | 16~60Vdc | Maximum Output Power : | 800VA |
| Max. Input Current : | 14Ax2 | Output Power Factor : | >0.99 |
| Input Shot-circuit Current : | 25Ax2 | Total Harmonic Distortion : | <3% |
| Nominal Grid Voltage : | 230Vac | Protection Level : | IP67 |
| Nominal Grid Frequency : | 50Hz/60Hz | Degree of Protection : | I |
| Operating Temperature : | -40~+65°C | Overvoltage Level : | PV II, Grid III |

MSA International SA rue industrie 12 3895 Foetz

Note:

- 1.The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
- 2.Label is attached on the back of enclosure and visible after installation
- 3.Labels of other models are as the same with **AB800A**'s except for the parameters of rating.

Equipment Under Testing:

– **AB800A**

Variant models:

- AB400A
- AB600A

The variant models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology.
- Same control algorithm.
- Output power within $1/\sqrt{10}$ and 2 times of the rated output power of the EUT or Modular inverters.
- Same Firmware Version.

The models of AB400A, AB600A and AB800A are identical on topological schematic circuit diagram and control solution codes.

The results obtained apply only to the particular sample tested that is the subject of the present test report.

The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a point (~~comma~~) is used as the decimal separator.

Following table shows the full ratings of all the models referenced in this report, marked in **bold letters** is the one subjected to testing:

| Model | AB400A | AB600A | AB800A |
|-----------------------------|-----------------|---------------|---------------|
| PV Input | | | |
| Number of MPPT Trackers | 2 | | |
| Max. Input Voltage | 60 Vdc | | |
| Start-up Operating Voltage | 30 Vdc | | |
| Operating Voltage Range | 16V-60 Vdc | | |
| MPPT Voltage Range | 33V-55 Vdc | | |
| Max. Input Current | 7 A * 2 | 12 A * 2 | 14 A * 2 |
| Max. Short Current | 15 A * 2 | 20 A * 2 | 25 A * 2 |
| AC Output | | | |
| Nominal Grid Voltage | L/N/PE, 230Vac | | |
| Nominal Grid Frequency | 50 Hz | | |
| Rated AC Power | 400 W | 600 W | 800 W |
| Max. AC Power | 400 VA | 600 VA | 800 VA |
| Rated AC Current | 1.74 A | 2.60 A | 3.48 A |
| Output Power Factor | >0.99 | | |
| General Data | | | |
| Operating temperature range | -40 °C ~ +65 °C | | |
| Protection degree | IP67 | | |
| Protective class | Class I | | |
| Altitude | Max. 2000m | | |
| Cooling method | Natural Cooling | | |
| Topology | Transformer | | |

2.3. REFERENCE VALUES

The values presented in the following table have been used for calculation of referenced values (p.u.; %) through the report.

| Reference Values for the EUT | |
|--|------|
| Rated power, P_n in W | 800 |
| Design active power, P_D in W ⁽¹⁾ | 720 |
| Maximun apparent power, S max in VA | 800 |
| Rated wind speed (only WT), v_n in m/s | N/A |
| Rated current, I_n in A | 3.48 |
| Rated output voltage, (Line to Neutral) U_n in Vac | 230 |
| Note: In this report p.u. values are calculated as follows: -For Active & Reactive Power p.u values are reference to S_n -For Currents p.u values, the reference is always I_n -For Voltages p.u values, the reference is always U_n | |

⁽¹⁾ Manufacturer's declaration: P_D equals to 0.9 times of Rated AC Output power, according to measured P_D ≈ 0.9P_n (720 W)

2.4. TEST EQUIPMENT LIST

| From | No. | Equipment Name | Trademark / Model No. | Equipment No. | Calibration Period |
|------|-----|------------------------------|----------------------------|---------------|--------------------------|
| SGS | 1 | Power analyzer | ZLG/PA6004H-P0004-2159 | SUZE600303 | 2023/11/05 to 2024/11/04 |
| | 2 | Digital Oscilloscope | Tektronix / MSO46 4-BW-500 | ATC550903 | 2023/07/13 to 2024/07/12 |
| | 3 | Oscilloscope probe | Tektronix/C188090 | ATC550904 | 2023/08/08 to 2024/08/07 |
| | 4 | Current probe | HIOKI/CT6873 | SUZE600807 | 2023/09/08 to 2024/09/07 |
| | 5 | Current probe | HIOKI/CT6873 | SUZE600808 | 2023/09/08 to 2024/09/07 |
| | 6 | Voltage probe | CYBERTEK/CP1000A | SUZE600801 | 2023/09/08 to 2024/09/07 |
| | 7 | Voltage probe | CYBERTEK/CP1000A | SUZE600802 | 2023/09/08 to 2024/09/07 |
| | 8 | Temperature & Humidity meter | Testo/175-H1 | SUZE601701 | 2023/05/09 to 2024/05/08 |
| | 9 | Power analyzer | DEWTRON/TRIONet | SUZE600302 | 2023/08/10 to 2024/08/09 |

Note: Voltage direct measurement through power analyzer, the voltage probes and current probe were used with the digital oscilloscope. All measurement equipment was used inside their corresponding calibration period. Copy of all calibration certificates are available at the laboratory for reference.

2.5. MEASUREMENT UNCERTAINTY

Associated uncertainties through measurements showed in this report are the maximum allowable uncertainties.


| Magnitude | Uncertainty |
|-----------------------|-------------|
| Voltage measurement | ±1.5 % |
| Current measurement | ±2.0 % |
| Frequency measurement | ±0.2 % |
| Time measurement | ±0.2 % |
| Power measurement | ±2.5 % |
| Phase Angle | ±1 ° |
| Temperature | ±3 °C |

Note1: Measurement uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

2.6. TEST SET UP OF THE DIFFERENT STANDARD

Below is the simplified construction of the test set up.



Different equipments have been used to take measures as shown in chapter 2.4. Current clamps and voltage probes have been connected to the inverter input / output for all the tests.

All the tests described in the following pages have used this specified test setup.

The test bench used includes:

| EQUIPMENT | TRADEMARK / MODEL | RATED CHARACTERISTICS | OWNER / ID.CODE |
|-----------|---------------------------------|-----------------------|-----------------|
| AC source | WAGO / WLPA-330150kVA-D-W | 60 kVA max. 45-65 Hz | SUZE600101 |
| DC source | EA/PSI 11500-60 | 1500V, 60A max. | SUZE600201 |
| RLC load | KAIXIANG / AC400V-450.99kVA-RLC | 450 kW, 450kvar | SUZE660101 |

2.7. FACTORY INFORMATION

Factory Name.....: Shenzhen Donnergy Technology Co., Ltd
 Factory Address.....: 6F Building 8, Xianan Third Industrial Zone, Shangcun Community, Gongming Street, Guangming District, Shenzhen, China

2.8. DEFINITIONS

| | | | |
|---------------------|--|----------------|-------------------------------|
| EUT | Equipment Under Testing | Hz | Hertz |
| A | Ampere | V | Volt |
| Un | Nominal Voltage | p.u | Per unit |
| In | Nominal Current | Pn | Rated Active Power |
| Ia | Active Current | Qn | Rated Reactive Power |
| Ir | Reactive Current | Sn | Rated Apparent Power |
| MV | Medium Voltage | THC | Total Harmonic Current |
| LV | Low Voltage | TDD | Total Demand Distortion |
| UVRT | Under-Voltage Ride Through | I _h | Harmonic Current |
| OVRT | Over-Voltage Ride Through | Plt | Severity of Flicker Long-Term |
| Pst | Severity of Flicker Short-Term | ms | Millisecond |
| dc | Maximum Variation of Voltage | s | Second |
| d max | Maximum Absolute Value of Voltage Variation | min | Minute |
| fn | Nominal frequency | P | Active Power |
| IGBT | Insulated-Gate Bipolar Transistor | Q | Reactive Power |
| RMS | Root Mean Square | PF | Power Factor |
| S _{k, fic} | Short-circuit apparent power | Nr. | Number |
| AC | Alternating Current | POC | Point of Connection |
| DC | Direct Current | Meas. | Measured |
| DSO | Distribution System Operator | Des. | Desired |
| EES | Electrical energy storage system | PGU | Power Generating Unit |
| EES | Electrical energy storage | P _D | Design active power |
| Pmax | Maximum active power | P _M | Momentary active power |
| P _A | Available active power | Smax | Maximum apparent power |

3. RESUME OF TEST RESULTS

INTERPRETATION KEYS

- Test object does meet the requirement.....: **P** Pass
- Test object does not meet the requirement: **F** Fails
- Test case does not apply to the test object.....: **N/A** Not applicable
- To make a reference to a table or an annex.....: See additional sheet
- To indicate that the test has not been realized: **N/R** Not realized

| EN 50549-1:2019 – Requirements for plant category Type B have been considered. | | | | |
|--|------------------|---|----------------|--------------------|
| REPORT SECTION | STANDARD SECTION | CHAPTER OF THE STANDARD | Plant category | Result |
| 4.1 | 4.4 | Normal operating range | -- | -- |
| 4.1.1 | 4.4.2 | Operating frequency range | ≥A | P |
| 4.1.2 | 4.4.3 | Minimal requirement for active power delivery at underfrequency | ≥A | P |
| 4.1.3 | 4.4.4 | Continuous operating voltage range | ≥A | P |
| 4.2 | 4.5 | Immunity to disturbances | ≥A | P |
| 4.2.1 | 4.5.2 | Rate of change of frequency (ROCOF) immunity | ≥A | P |
| 4.2.2 | 4.5.3 | Under-voltage ride through (UVRT) | B | P |
| 4.2.3 | 4.5.4 | Over-voltage ride through (OVRT) | ≥A | P |
| 4.3 | 4.6 | Active response to frequency deviation | ≥A | P |
| 4.3.1 | 4.6.1 | Power response to overfrequency | ≥A | P |
| 4.3.2 | 4.6.2 | Power response to underfrequency | ≥A | N/A |
| 4.4 | 4.7 | Power response to voltage changes | ≥A | P |
| 4.4.1 and 4.4.2 | 4.7.2 | Voltage support by reactive power | ≥A | P |
| 4.4.3 | 4.7.3 | Voltage related active power reduction | ≥A | P |
| 4.4.4 | 4.7.4 | Short circuit current requirements on generating plants | B | N/A |
| 4.5 | 4.8 | EMC and power quality | ≥A | N/R ⁽¹⁾ |
| 4.5.1 | 4.8 | Harmonic emissions | ≥A | P |
| 4.5.2 | 4.8 | Flicker and voltage fluctuations | ≥A | P |
| 4.6 | 4.9 | Interface protection | ≥A | P |
| 4.6.1 | 4.9.3 | Requirements on voltage and frequency protection | ≥A | P |
| 4.6.2 | 4.9.4 | Means to detect island situation | ≥A | P |
| 4.6.3 | 4.9.5 | Digital input to the interface protection | ≥A | P |
| 4.7 | 4.10 | Connection and starting to generate electrical power | ≥A | P |
| 4.7.1 | 4.10.2 | Automatic reconnection after tripping | ≥A | P |
| 4.7.2 | 4.10.3 | Starting to generate electrical power | ≥A | P |
| 4.7.3 | 4.10.4 | Synchronization | ≥A | P |
| 4.8 | 4.11 | Ceasing and reduction of active power on set point | ≥A | P |
| 4.8.1 | 4.11.1 | Ceasing active power | ≥A | P |
| 4.8.2 | 4.11.2 | Reduction of active power on set point | B | P |
| 4.9 | 4.13 & 4.3 | Requirements regarding single fault tolerance of interface protection system and interface switch | ≥A | N/R ⁽²⁾ |

Note: Decision Rule of Statements of conformity evaluated according to Guidelines ILAC G8:09/2019 and IEC 115:2023 (4.3.3 / 4.4) & ISO/IEC Guide 98-4 (8.3.12).
Decision Rules used: Binary Statement for Simple Acceptance (Guard Band with respect to the limit w=0).
Specific Risk: Probability of False Accept or Reject lower than 50 %, (PFA / PFR < 50 %)
Measurement uncertainty is not applied when statements of conformity is the simple acceptance.
For more information see ILAC G8/09 & 115 Guidelines.

The compliances with these requirements are stated in the following test reports:

(1) EN IEC 61000-6-3: 2021; EN IEC 61000-6-1: 2019: Test Report no.GZCR231100125005C02 , issued by SGS-SCTS Standards Technical Services Co., Ltd. Guangzhou Branch, on May 28 of 2024. NVLAP LAB CODE 200611-0.

(2) IEC 62109-1: 2010 and IEC 62109-2: 2011: Test Report no. GZES240100138501 and GZES240100138502, issued by SGS-SCTS Standards Technical Services Co., Ltd. Guangzhou Branch, on February 19 of 2024. GAC ATL 0032.

Conclusion: From the test results on the submitted sample, we conclude that it complies with the requirements of the standard.

4. TEST RESULTS

4.1. NORMAL OPERATING RANGE

4.1.1. Operating frequency range

The test has been performed according to the clause 4.4.2 of the standard, the requirement is as follows:

Table 1 — Minimum time periods for operation in underfrequency and overfrequency situations

| Frequency Range | Time period for operation Minimum requirement | Time period for operation stringent requirement |
|-------------------|--|--|
| 47,0 Hz – 47,5 Hz | not required | 20 s |
| 47,5 Hz – 48,5 Hz | 30 min ^a | 90 min |
| 48,5 Hz – 49,0 Hz | 30 min ^a | 90 min ^a |
| 49,0 Hz – 51,0 Hz | Unlimited | Unlimited |
| 51,0 Hz – 51,5 Hz | 30 min ^a | 90 min |
| 51,5 Hz – 52,0 Hz | not required | 15 min |


^a Respecting the legal framework, it is possible that longer time periods are required by the responsible party in some synchronous areas.

“Time period for operation, stringent requirement” (second column of the table) has been considered for this test.


In order to verify this function, parameter settings as in the following table have been considered to perform the test. Time requirements considered are the “stringent requirement” according to Table 1 of the standard:

| Steps | f (Hz) Setting | Time requirement | f Measured (Hz) | Time Measured (min) | Power measured (p.u.) |
|-------|----------------|------------------|-----------------|---------------------|-----------------------|
| 1 | 47.00 | >20 s | 47.00 | 3.00 | 1.002 |
| 2 | 47.50 | >90 min | 47.50 | 95.00 | 1.000 |
| 3 | 48.50 | >90 min | 48.50 | 100.00 | 1.007 |
| 4 | 50.00 | Unlimited | 50.00 | 2.83 | 1.006 |
| 5 | 51.50 | >90 min | 51.50 | 95.00 | 0.999 |
| 6 | 52.00 | >15 min | 52.00 | 16.50 | 1.003 |


Test results are represented at diagrams below.




Test 3 - 48.5 Hz




Test 4 - 50.0 Hz



Test 5 - 51.5 Hz



Test 6 - 52.0 Hz



4.1.2. Minimal requirement for active power delivery at underfrequency

The test has been performed according to the clause 4.4.3 of the standard, the requirement is as follows:

A generating plant shall be resilient to the reduction of frequency at the point of connection while reducing the maximum active power as little as possible.

The admissible active power reduction due to underfrequency is limited by the full line in Figure 5 of the standard and is characterized by a maximum allowed reduction rate of 10 % of P_{max} per 1 Hz for frequencies below 49.5 Hz.

It is possible that a more stringent power reduction characteristic is required by the responsible party. Nevertheless this requirement is expected to be limited to an admissible active power reduction represented by the dotted line in Figure 5 which is characterised by a reduction rate of 2 % of the maximum power P_{max} per 1 Hz for frequencies below 49 Hz.





Figure 5 — Maximum allowable power reduction in case of underfrequency

As defined by manufacturer, the power will not reduce when the frequency is below 49.5 Hz.

| Step | f (Hz) Setting | f meas. (Hz) | Time start (s) | Time end (s) | Time meas. (s) | Time (s) | P desired (p.u.) | P meas. (p.u.) | P deviation (p.u.) |
|------|----------------|--------------|----------------|--------------|----------------|----------|------------------|----------------|--------------------|
| 1 | 50.00 ± 0.05 | 50.00 | 0.0 | 120.8 | 120.8 | >60 | 1.000 | 1.006 | +0.006 |
| 2 | 49.50 ± 0.05 | 49.50 | 121.8 | 240.4 | 118.6 | >60 | 1.000 | 1.006 | +0.006 |
| 3 | 49.00 ± 0.05 | 49.00 | 241.8 | 361.0 | 119.2 | >60 | 1.000 | 1.005 | +0.005 |
| 4 | 48.50 ± 0.05 | 48.50 | 361.8 | 480.4 | 118.6 | >60 | 1.000 | 1.006 | +0.006 |
| 5 | 48.00 ± 0.05 | 48.00 | 481.8 | 601.0 | 119.2 | >60 | 1.000 | 1.008 | +0.008 |
| 6 | 47.50 ± 0.05 | 47.50 | 601.8 | 720.6 | 118.8 | >60 | 1.000 | 1.007 | +0.007 |
| 7 | 50.00 ± 0.05 | 50.00 | 721.8 | 840.0 | 118.2 | >60 | 1.000 | 1.008 | +0.008 |

Test results are represented at diagrams below.



4.1.3. Continuous operating voltage range

The test has been performed according to the clause 4.4.4 of the standard, the requirement is as follows:


The generating plant shall be capable of operating continuously when the voltage at the point of connection stays within the range of 85%Un to 110%Un.

In order to verify this function, the parameter setting is as follows to perform the test:

| Step | V desired (p.u.) | P desired (p.u.) | V meas. (p.u.) | P meas. (p.u.) | Time start (s) | Time end (s) | Time meas. (s) |
|------|------------------|------------------|----------------|----------------------|----------------|--------------|----------------|
| 1 | 1.000 | 1.000 | 1.000 | 1.000 | 0.0 | 299.8 | 299.8 |
| 2 | 0.850 | 1.000 | 0.850 | 0.850 ⁽¹⁾ | 301.2 | 600.4 | 299.2 |
| 3 | 1.000 | 1.000 | 1.000 | 1.001 | 601.2 | 899.2 | 298.0 |
| 4 | 1.100 | 1.000 | 1.100 | 0.988 | 901.2 | 1200.0 | 298.8 |

⁽¹⁾ Active power reduction is allowed due to current limitation.

Test results are represented at diagrams below.



4.2. IMMUNITY TO DISTURBANCES

4.2.1. Rate of change of frequency (ROCOF) immunity


The test has been performed according to the clause 4.5.2 of the standard, the requirement is as follows:

- **Non-synchronous generating technology: at least 2 Hz/s**

The ROCOF immunity is defined with a sliding measurement window of 500 ms as follows:


| Steps | f (Hz) | ROCOF requirement (Hz/s) | Step time | Measured frequency (Hz) | Measured step change time (s) | ROCOF meas. (Hz/s) | Disconnection |
|-------|--------------|--------------------------|-----------|-------------------------|-------------------------------|--------------------|---------------|
| 1 | 50.00 ± 0.05 | N/A | >10 s | 50.00 | -- | -- | No |
| 2 | 52.00 ± 0.05 | >2 | >10 s | 52.00 | 0.8 | +2.5 | No |
| 3 | 50.00 ± 0.05 | >2 | >10 s | 50.00 | 0.8 | -2.5 | No |
| 4 | 48.00 ± 0.05 | >2 | >10 s | 48.00 | 0.8 | -2.5 | No |
| 5 | 50.00 ± 0.05 | >2 | >10 s | 50.00 | 0.8 | +2.5 | No |

Test results are represented at diagrams below.




4.2.2. Under-voltage ride through (UVRT)

The requirements are defined in the clause 4.5.3 of the standard.
The test uses the most stringent line in the following figure.



4.2.2.1. No load Test

It is not specified in the reference standard, but following tolerances have been applied. Tolerances for drop depth and duration during no-load tests shall not exceed the values shown in the next figure:




The tolerance for voltage magnitude is $\pm 5\%U_n$ for the period before and during the voltage drop. The tolerance for voltage magnitude is $\pm 10\%U_n$ during the period after voltage is recovered. The tolerance range for both drop duration and rise time prefers 40 ms.


Test results of different no-load cases performed are offered below:

| No Load | | | | | | | | |
|------------|-------------------------------------|---------------------------------|------------------------|--------------------------------------|-----------------------|------------------------|--------------------------|-----------------------------------|
| Phase type | Residual voltage desired (% U_n) | Voltage before fault (% U_n) | Voltage drop time (ms) | Residual voltage Measured (% U_n) | Dip time desired (ms) | Dip time measured (ms) | Power recovery time (ms) | Voltage after recovery (% U_n) |
| 1 ph | 0.0-5.0 | 100.2 | 19 | 3.0 | ≥ 250 | 259 | -- | 99.4 |
| 1 ph | 25.0 | 100.2 | 18 | 25.0 | ≥ 938 | 978 | -- | 100.4 |
| 1 ph | 50.0 | 100.0 | 19 | 50.1 | ≥ 1797 | 1810 | -- | 99.7 |
| 1 ph | 75.0 | 100.2 | 17 | 75.0 | ≥ 2656 | 2703 | -- | 100.1 |

Test results are graphically represented in the following pages.



Voltage Recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|-----------|-----------|
| U1_tRMS_rc@AC [V] | 7.005925 | 228.5468 | 221.5408 |
| I1_tRMS_rc@AC [A] | 0.018540 | 0.018833 | 2.934e-4 |
| P_t_rc@AC [W] | -4.829e-3 | -0.047126 | -0.042298 |
| Q_t_rc@AC [var] | 0.129800 | 4.304053 | 4.174253 |
| S_t_rc@AC [VA] | 0.129890 | 4.304311 | 4.174421 |

L-N fault

No Load


Residual voltage: 25 %Un

Voltage Drop Time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|-----------|-----------|
| U1_tRMS_rc@AC [V] | 230.3665 | 57.61111 | -172.7554 |
| I1_tRMS_rc@AC [A] | 0.019376 | 0.018871 | -5.051e-4 |
| P_t_rc@AC [W] | 0.041021 | -0.043106 | -0.084127 |
| Q_t_rc@AC [var] | 4.463450 | 1.086333 | -3.377117 |
| S_t_rc@AC [VA] | 4.463638 | 1.087188 | -3.376451 |

Dip Time



| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|-----------|
| 0:18.0950257 | 0:19.0733618 | 0:19.0733618 | 0.9783361 |
| U1_tRMS_rc@AC [V] | 57.61111 | 57.50113 | -0.109978 |
| I1_tRMS_rc@AC [A] | 0.018871 | 0.019348 | 4.771e-4 |
| P_t_rc@AC [W] | -0.043106 | 0.012063 | 0.055170 |
| Q_t_rc@AC [var] | 1.086333 | 1.112481 | 0.026148 |
| S_t_rc@AC [VA] | 1.087188 | 1.112546 | 0.025358 |

Voltage recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|-----------|
| 0:19.0767365 | 0:19.0988650 | 0:19.0988650 | 0.0221285 |
| U1_tRMS_rc@AC [V] | 57.69662 | 230.9868 | 173.2901 |
| I1_tRMS_rc@AC [A] | 0.019183 | 0.019651 | 4.681e-4 |
| P_t_rc@AC [W] | -3.128e-3 | 0.151356 | 0.154483 |
| Q_t_rc@AC [var] | 1.106767 | 4.536525 | 3.429758 |
| S_t_rc@AC [VA] | 1.106771 | 4.539049 | 3.432278 |

L-N fault

No Load


Residual voltage: 50 %Un

Voltage Drop Time





| 时间 [s] | A | B | 间隔 |
|-------------------|---------------|------------|-----------|
| 0:18.13785530 | 0:18.15714206 | 0.01928677 | |
| U1_tRMS_rc@AC [V] | 230.0382 | 115.3416 | -114.6967 |
| I1_tRMS_rc@AC [A] | 0.020818 | 0.020586 | -2.325e-4 |
| P_t_rc@AC [W] | -0.043081 | -0.109563 | -0.066481 |
| Q_t_rc@AC [var] | 4.788786 | 2.371861 | -2.416925 |
| S_t_rc@AC [VA] | 4.788980 | 2.374390 | -2.414590 |

Dip Time



| 时间 [s] | A | B | 间隔 |
|-------------------|---------------|------------|-----------|
| 0:18.15631205 | 0:19.96632391 | 1.81001186 | |
| U1_tRMS_rc@AC [V] | 115.7210 | 115.3972 | -0.323799 |
| I1_tRMS_rc@AC [A] | 0.020619 | 0.020793 | 1.741e-4 |
| P_t_rc@AC [W] | -0.112879 | -0.062630 | 0.050249 |
| Q_t_rc@AC [var] | 2.383404 | 2.398675 | 0.015272 |
| S_t_rc@AC [VA] | 2.386075 | 2.399493 | 0.013418 |






4.2.2.2. Load Tests: Partial load (20 %Pn)


Test results of different 20%Pn load cases performed are offered below:

| 20 %Pn Load | | | | | | | | |
|-------------|--------------------------------|----------------------------|------------------------|---------------------------------|-----------------------|------------------------|--------------------------|------------------------------|
| Phase type | Residual voltage desired (%Un) | Voltage before fault (%Un) | Voltage drop time (ms) | Residual voltage Measured (%Un) | Dip time desired (ms) | Dip time measured (ms) | Power recovery time (ms) | Voltage after recovery (%Un) |
| 1 ph | 0.0-5.0 | 100.0 | 20 | 3.0 | ≥ 250 | 258 | 138 | 100.3 |
| 1 ph | 25.0 | 100.2 | 19 | 25.0 | ≥ 938 | 978 | 186 | 99.9 |
| 1 ph | 50.0 | 99.8 | 18 | 50.0 | ≥ 1797 | 1808 | 157 | 100.0 |
| 1 ph | 75.0 | 100.2 | 18 | 75.0 | ≥ 2656 | 2676 | 238 | 99.9 |

Test results are graphically represented at following pages.



Power Recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 6.891031 | 230.7578 | 223.8668 |
| I1_tRMS_rc@AC [A] | 0.019807 | 0.706888 | 0.687080 |
| P_t_rc@AC [W] | -3.614e-3 | 162.0366 | 162.0402 |
| Q_t_rc@AC [var] | 0.136446 | 18.76804 | 18.63160 |
| S_t_rc@AC [VA] | 0.136494 | 163.1199 | 162.9834 |

L-N fault


20%Pn Load

Residual voltage: 25%Un


Voltage Drop time



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 230.3974 | 57.54622 | -172.8512 |
| I1_tRMS_rc@AC [A] | 0.740263 | 3.401532 | 2.661268 |
| P_t_rc@AC [W] | 163.3842 | 20.64318 | -142.7410 |
| Q_t_rc@AC [var] | 48.93406 | 194.6537 | 145.7197 |
| S_t_rc@AC [VA] | 170.5547 | 195.7453 | 25.19054 |

DipTime


| 时间 [s] | A | B | 间隔 |
|---------------------|----------|-----------|-----------|
| ● U1_tRMS_rc@AC [V] | 57.54622 | 57.52131 | -0.024906 |
| ● I1_tRMS_rc@AC [A] | 3.401532 | 0.023652 | -3.377879 |
| ● P_t_rc@AC [W] | 20.64318 | -2.615e-3 | -20.64579 |
| ● Q_t_rc@AC [var] | 194.6537 | 1.360514 | -193.2932 |
| ● S_t_rc@AC [VA] | 195.7453 | 1.360516 | -194.3848 |


Power Recovery time


| 时间 [s] | A | B | 间隔 |
|---------------------|-----------|----------|----------|
| ● U1_tRMS_rc@AC [V] | 57.71861 | 229.6781 | 171.9595 |
| ● I1_tRMS_rc@AC [A] | 0.024426 | 0.707734 | 0.683309 |
| ● P_t_rc@AC [W] | -0.021145 | 161.7876 | 161.8087 |
| ● Q_t_rc@AC [var] | 1.409667 | 15.73703 | 14.32737 |
| ● S_t_rc@AC [VA] | 1.409826 | 162.5511 | 161.1413 |

L-N fault


20%Pn Load Residual voltage: 50%Un

Voltage Drop time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 229.5272 | 114.9849 | -114.5423 |
| I1_tRMS_rc@AC [A] | 1.097175 | 3.815746 | 2.718571 |
| P_t_rc@AC [W] | 170.4334 | 118.0598 | -52.37360 |
| Q_t_rc@AC [var] | 185.3957 | 422.5709 | 237.1752 |
| S_t_rc@AC [VA] | 251.8315 | 438.7531 | 186.9216 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 114.9849 | 115.1918 | 0.206970 |
| I1_tRMS_rc@AC [A] | 3.815746 | 0.033837 | -3.781909 |
| P_t_rc@AC [W] | 118.0598 | 4.453e-3 | -118.0554 |
| Q_t_rc@AC [var] | 422.5709 | 3.897778 | -418.6731 |
| S_t_rc@AC [VA] | 438.7531 | 3.897780 | -434.8553 |


Power Recovery time


| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 115.8882 | 229.9892 | 114.1011 |
| I1_tRMS_rc@AC [A] | 0.035192 | 0.703974 | 0.668782 |
| P_t_rc@AC [W] | -0.081555 | 161.0709 | 161.1525 |
| Q_t_rc@AC [var] | 4.077526 | 16.42623 | 12.34870 |
| S_t_rc@AC [VA] | 4.078341 | 161.9063 | 157.8280 |

L-N fault


20%Pn Load

Residual voltage: 75%Un

Voltage Drop time



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 230.4390 | 172.5601 | -57.87897 |
| I1_tRMS_rc@AC [A] | 0.705793 | 0.547056 | -0.158736 |
| P_t_rc@AC [W] | 161.9278 | 57.16507 | -104.7627 |
| Q_t_rc@AC [var] | 15.22733 | 75.12343 | 59.89609 |
| S_t_rc@AC [VA] | 162.6422 | 94.40008 | -68.24210 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|-----------|-----------|
| U1_tRMS_rc@AC [V] | 172.5601 | 172.6268 | 0.066788 |
| I1_tRMS_rc@AC [A] | 0.547056 | 0.045250 | -0.501806 |
| P_t_rc@AC [W] | 57.16507 | -3.594e-3 | -57.16866 |
| Q_t_rc@AC [var] | 75.12343 | 7.811443 | -67.31199 |
| S_t_rc@AC [VA] | 94.40008 | 7.811444 | -86.58863 |

Power Recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 172.6681 | 229.8471 | 57.17899 |
| I1_tRMS_rc@AC [A] | 0.045626 | 0.699158 | 0.653532 |
| P_t_rc@AC [W] | -0.076744 | 159.6925 | 159.7692 |
| Q_t_rc@AC [var] | 7.877718 | 17.96136 | 10.08364 |
| S_t_rc@AC [VA] | 7.878092 | 160.6994 | 152.8213 |


4.2.2.3. Load Tests: Partial load (> 90 %Pn)

Test results of full power cases performed are offered below:

| > 90 %Pn Load | | | | | | | | |
|-------------------------|---------------------------------------|-----------------------------------|-------------------------------|--|------------------------------|-------------------------------|---------------------------------|-------------------------------------|
| Phase type | Residual voltage desired (%Un) | Voltage before fault (%Un) | Voltage drop time (ms) | Residual voltage Measured (%Un) | Dip time desired (ms) | Dip time measured (ms) | Power recovery time (ms) | Voltage after recovery (%Un) |
| 1 ph | 0.0-5.0 | 100.2 | 19 | 3.0 | ≥ 250 | 259 | 736 | 100.0 |
| 1 ph | 25.0 | 100.0 | 18 | 25.0 | ≥ 938 | 979 | 273 | 100.0 |
| 1 ph | 50.0 | 100.0 | 18 | 50.0 | ≥ 1797 | 1810 | 629 | 100.0 |
| 1 ph | 75.0 | 100.0 | 18 | 75.0 | ≥ 2656 | 2692 | 421 | 100.0 |

Test results are graphically represented at following pages.




Power Recovery Time


| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 6.967752 | 230.0735 | 223.1057 |
| I1_tRMS_rc@AC [A] | 0.018866 | 3.478077 | 3.459211 |
| P_t_rc@AC [W] | -9.429e-3 | 797.3329 | 797.3424 |
| Q_t_rc@AC [var] | 0.131113 | 67.83505 | 67.70394 |
| S_t_rc@AC [VA] | 0.131452 | 800.2134 | 800.0819 |

L-N fault

100%Pn Load

Residual voltage: 25%Un

Voltage Drop time



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 229.9616 | 57.47577 | -172.4858 |
| I1_tRMS_rc@AC [A] | 3.611303 | 0.947639 | -2.663664 |
| P_t_rc@AC [W] | 801.0609 | 2.739065 | -798.3218 |
| Q_t_rc@AC [var] | 219.0129 | 54.39735 | -164.6155 |
| S_t_rc@AC [VA] | 830.4608 | 54.46626 | -775.9946 |

DipTime





| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 57.47577 | 57.40454 | -0.071228 |
| I1_tRMS_rc@AC [A] | 0.947639 | 0.022930 | -0.924709 |
| P_t_rc@AC [W] | 2.739065 | 3.597e-4 | -2.738705 |
| Q_t_rc@AC [var] | 54.39735 | 1.316269 | -53.08108 |
| S_t_rc@AC [VA] | 54.46626 | 1.316269 | -53.14999 |

Power Recovery Time



| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 57.56044 | 230.0092 | 172.4487 |
| I1_tRMS_rc@AC [A] | 0.022973 | 3.478631 | 3.455658 |
| P_t_rc@AC [W] | -0.010447 | 796.7859 | 796.7963 |
| Q_t_rc@AC [var] | 1.322283 | 72.93474 | 71.61246 |
| S_t_rc@AC [VA] | 1.322324 | 800.1170 | 798.7947 |




Power Recovery Time


| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|----------|
| U1_tRMS_rc@AC [V] | 115.2192 | 230.0584 | 114.8392 |
| I1_tRMS_rc@AC [A] | 0.033134 | 3.488174 | 3.455040 |
| P_t_rc@AC [W] | -0.054211 | 799.3460 | 799.4002 |
| Q_t_rc@AC [var] | 3.817285 | 70.89639 | 67.07911 |
| S_t_rc@AC [VA] | 3.817670 | 802.4839 | 798.6662 |

L-N fault


100%Pn Load

Residual voltage: 75%Un

Voltage Drop time



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 230.0230 | 172.5105 | -57.51257 |
| I1_tRMS_rc@AC [A] | 3.490792 | 2.322895 | -1.167898 |
| P_t_rc@AC [W] | 799.5894 | 119.4416 | -680.1478 |
| Q_t_rc@AC [var] | 73.52382 | 382.5090 | 308.9852 |
| S_t_rc@AC [VA] | 802.9626 | 400.7236 | -402.2390 |

DipTime



| 时间 [s] | A | B | 间隔 |
|---------------------|----------|-----------|-----------|
| ● U1_tRMS_rc@AC [V] | 172.5105 | 172.6048 | 0.094360 |
| ● I1_tRMS_rc@AC [A] | 2.322895 | 0.045234 | -2.277660 |
| ● P_t_rc@AC [W] | 119.4416 | -0.080714 | -119.5223 |
| ● Q_t_rc@AC [var] | 382.5090 | 7.807230 | -374.7017 |
| ● S_t_rc@AC [VA] | 400.7236 | 7.807647 | -392.9160 |

Power Recovery Time



| 时间 [s] | A | B | 间隔 |
|---------------------|-----------|----------|----------|
| ● U1_tRMS_rc@AC [V] | 172.6147 | 230.0514 | 57.43671 |
| ● I1_tRMS_rc@AC [A] | 0.045520 | 3.462344 | 3.416823 |
| ● P_t_rc@AC [W] | -0.049743 | 793.2045 | 793.2543 |
| ● Q_t_rc@AC [var] | 7.857301 | 72.56697 | 64.70967 |
| ● S_t_rc@AC [VA] | 7.857458 | 796.5170 | 788.6596 |

4.2.3. Over-voltage ride through (OVRT)

The test has been performed according to the clause 4.5.4 of the standard. The setting of over-voltage ride through capability is as follows:





Figure 8 — Over-voltage ride through capability

4.2.3.1 No load Test

It is not specified in the reference standard, but following tolerances have been applied. Tolerances for drop depth and duration during no-load tests shall not exceed the values shown in the next figure:




The tolerance for voltage magnitude is $\pm 5\%U_n$ for the period before and during the voltage drop. The tolerance for voltage magnitude is $\pm 10\%U_n$ during the period after voltage is recovered. The tolerance range for both drop duration and rise time prefers 40 ms.


Test results of different no-load cases performed are offered below:

| L-N fault | | | | | | | |
|--------------------------------|--------------------------|------------------------|---------------------------------|--------------|-------|--------------------------|------------------------------|
| Residual voltage Desired (%Un) | Voltage before sag (%Un) | Voltage Rise time (ms) | Residual voltage Measured (%Un) | DipTime (ms) | | Power Recovery time (ms) | Voltage after Recovery (%Un) |
| | | | | Desired | Meas. | | |
| 125.0 | 100.0 | 18 | 125.0 | > 100 | 112 | -- | 100.2 |
| 120.0 | 100.0 | 17 | 120.2 | > 5000 | 5072 | -- | 100.3 |
| 115.0 | 100.1 | 16 | 115.1 | > 60000 | 60929 | -- | 100.1 |

Test results are graphically represented at following pages.



Voltage recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 287.6895 | 230.3573 | -57.33229 |
| I1_tRMS_rc@AC [A] | 0.019990 | 0.019813 | -1.768e-4 |
| P_t_rc@AC [W] | 0.102921 | 0.015756 | -0.087166 |
| Q_t_rc@AC [var] | 5.750045 | 4.564128 | -1.185917 |
| S_t_rc@AC [VA] | 5.750966 | 4.564156 | -1.186810 |

L-N fault

No Load


Residual voltage: 120.0%Un

Voltage Rise time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|-----------|-----------|
| U1_tRMS_rc@AC [V] | 230.0850 | 276.4180 | 46.33301 |
| I1_tRMS_rc@AC [A] | 0.021173 | 0.021331 | 1.580e-4 |
| P_t_rc@AC [W] | 0.021300 | -0.024754 | -0.046054 |
| Q_t_rc@AC [var] | 4.871474 | 5.896135 | 1.024661 |
| S_t_rc@AC [VA] | 4.871521 | 5.896187 | 1.024666 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|---------------|------------|
| 0:18.18980492 | | 0:23.26208661 | 5.07228169 |
| U1_tRMS_rc@AC [V] | 276.4180 | 275.9498 | -0.468170 |
| I1_tRMS_rc@AC [A] | 0.021331 | 0.021214 | -1.164e-4 |
| P_t_rc@AC [W] | -0.024754 | -0.055549 | -0.030795 |
| Q_t_rc@AC [var] | 5.896135 | 5.853827 | -0.042308 |
| S_t_rc@AC [VA] | 5.896187 | 5.854091 | -0.042096 |

Voltage recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|---------------|------------|
| 0:23.27226895 | | 0:23.28922058 | 0.01695163 |
| U1_tRMS_rc@AC [V] | 275.9117 | 230.6937 | -45.21797 |
| I1_tRMS_rc@AC [A] | 0.021488 | 0.020995 | -4.935e-4 |
| P_t_rc@AC [W] | 0.031879 | 0.133824 | 0.101944 |
| Q_t_rc@AC [var] | 5.928799 | 4.841520 | -1.087279 |
| S_t_rc@AC [VA] | 5.928885 | 4.843369 | -1.085515 |

L-N fault

No Load


Residual voltage: 115.0%Un

Voltage Rise time




| 时间 [s] | A | B | 间隔 |
|-------------------|-----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 230.2387 | 264.6546 | 34.41591 |
| I1_tRMS_rc@AC [A] | 0.019336 | 0.019079 | -2.564e-4 |
| P_t_rc@AC [W] | -0.062210 | 0.043005 | 0.105215 |
| Q_t_rc@AC [var] | 4.451374 | 5.049220 | 0.597846 |
| S_t_rc@AC [VA] | 4.451809 | 5.049403 | 0.597594 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 264.6546 | 264.4737 | -0.180878 |
| I1_tRMS_rc@AC [A] | 0.019079 | 0.019855 | 7.760e-4 |
| P_t_rc@AC [W] | 0.043005 | 0.159885 | 0.116881 |
| Q_t_rc@AC [var] | 5.049220 | 5.248756 | 0.199537 |
| S_t_rc@AC [VA] | 5.049403 | 5.251191 | 0.201788 |

Voltage recovery time





| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|-----------|
| | 1:19.3782639 | 1:19.3945336 | 0.0162696 |
| U1_tRMS_rc@AC [V] | 264.4139 | 230.1594 | -34.25450 |
| I1_tRMS_rc@AC [A] | 0.019737 | 0.019567 | -1.693e-4 |
| P_t_rc@AC [W] | 0.127890 | -2.980e-3 | -0.130869 |
| Q_t_rc@AC [var] | 5.217100 | 4.503618 | -0.713482 |
| S_t_rc@AC [VA] | 5.218668 | 4.503619 | -0.715048 |


4.2.3.2 Load Tests: Partial load (20%Pn)

Test results of 20%Pn power cases performed are offered below:

| L-N fault | | | | | | | |
|--------------------------------|--------------------------|------------------------|---------------------------------|--------------|-------|--------------------------|------------------------------|
| Residual voltage Desired (%Un) | Voltage before sag (%Un) | Voltage Rise time (ms) | Residual voltage Measured (%Un) | DipTime (ms) | | Power Recovery time (ms) | Voltage after Recovery (%Un) |
| | | | | Desired | Meas. | | |
| 125.0 | 100.0 | 18 | 125.1 | > 100 | 113 | 240 | 100.1 |
| 120.0 | 100.1 | 18 | 120.2 | > 5000 | 5281 | 243 | 100.1 |
| 115.0 | 100.0 | 17 | 115.0 | > 60000 | 60903 | 282 | 100.0 |

Test results are graphically represented at following pages.




Power Recovery time


| 时间 [s] | A | B | 间隔 |
|------------------|----------|----------|-----------|
| U1_rms_rc@AC [V] | 287.5248 | 230.2789 | -57.24597 |
| I1_rms_rc@AC [A] | 0.070621 | 0.705663 | 0.635041 |
| P_t_rc@AC [W] | 0.352910 | 161.5199 | 161.1670 |
| Q_t_rc@AC [var] | 20.30236 | 17.81344 | -2.488926 |
| S_t_rc@AC [VA] | 20.30543 | 162.4993 | 142.1938 |


L-N fault

Partial load (20%Pn)


Residual voltage: 120.0%Un

Voltage Rise time


| 时间 [s] | A | B | 间隔 |
|------------------|----------|----------|-----------|
| U1_rms_rc@AC [V] | 230.2055 | 276.5371 | 46.33165 |
| I1_rms_rc@AC [A] | 0.710933 | 0.245833 | -0.465100 |
| P_t_rc@AC [W] | 162.6162 | 31.32406 | -131.2921 |
| Q_t_rc@AC [var] | 18.46136 | 60.33529 | 41.87392 |
| S_t_rc@AC [VA] | 163.6608 | 67.98193 | -95.67882 |

DipTime


| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|-----------|-----------|
| 0:18.6230327 | 0:23.9039966 | 5.2809639 | |
| U1_tRMS_rc@AC [V] | 276.5371 | 275.9352 | -0.601990 |
| I1_tRMS_rc@AC [A] | 0.245833 | 0.069293 | -0.176540 |
| P_t_rc@AC [W] | 31.32406 | -0.160229 | -31.48429 |
| Q_t_rc@AC [var] | 60.33529 | 19.11963 | -41.21565 |
| S_t_rc@AC [VA] | 67.98193 | 19.12030 | -48.86163 |

Power Recovery time



| 时间 [s] | A | B | 间隔 |
|-------------------|---------------|------------|-----------|
| 0:23.90474334 | 0:24.14751331 | 0.24276997 | |
| U1_tRMS_rc@AC [V] | 275.9352 | 230.2097 | -45.72548 |
| I1_tRMS_rc@AC [A] | 0.069293 | 0.705714 | 0.636421 |
| P_t_rc@AC [W] | -0.160229 | 161.3679 | 161.5281 |
| Q_t_rc@AC [var] | 19.11963 | 18.82388 | -0.295748 |
| S_t_rc@AC [VA] | 19.12030 | 162.4621 | 143.3418 |

L-N fault

Partial load (20%Pn)


Residual voltage: 115.0%Un

Voltage Rise time




| 时间 [s] | A | B | 间隔 |
|-------------------|----------|----------|-----------|
| U1_tRMS_rc@AC [V] | 230.0957 | 264.5118 | 34.41608 |
| I1_tRMS_rc@AC [A] | 0.703366 | 0.303573 | -0.399793 |
| P_t_rc@AC [W] | 160.6724 | 44.01782 | -116.6545 |
| Q_t_rc@AC [var] | 19.41875 | 67.15880 | 47.74005 |
| S_t_rc@AC [VA] | 161.8416 | 80.29865 | -81.54293 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|----------|-----------|-----------|
| U1_tRMS_rc@AC [V] | 264.5118 | 264.4684 | -0.043396 |
| I1_tRMS_rc@AC [A] | 0.303573 | 0.066145 | -0.237428 |
| P_t_rc@AC [W] | 44.01782 | -0.088461 | -44.10628 |
| Q_t_rc@AC [var] | 67.15880 | 17.49298 | -49.66581 |
| S_t_rc@AC [VA] | 80.29865 | 17.49321 | -62.80544 |

Power Recovery time




| 时间 [s] | A | B | 间隔 |
|---------------------|-----------|----------|-----------|
| ● U1_tRMS_rc@AC [V] | 264.4673 | 230.0707 | -34.39661 |
| ● I1_tRMS_rc@AC [A] | 0.066089 | 0.708116 | 0.642027 |
| ● P_t_rc@AC [W] | -0.159503 | 161.9855 | 162.1450 |
| ● Q_t_rc@AC [var] | 17.47757 | 17.39384 | -0.083731 |
| ● S_t_rc@AC [VA] | 17.47830 | 162.9167 | 145.4384 |


4.2.3.2 Load Tests: Full Load (> 90 %Pn)

Test results of full power cases performed are offered below:

| L-N fault | | | | | | | |
|--------------------------------|--------------------------|------------------------|---------------------------------|--------------|-------|--------------------------|------------------------------|
| Residual voltage Desired (%Un) | Voltage before sag (%Un) | Voltage Rise time (ms) | Residual voltage Measured (%Un) | DipTime (ms) | | Power Recovery time (ms) | Voltage after Recovery (%Un) |
| | | | | Desired | Meas. | | |
| 125.0 | 100.0 | 18 | 125.1 | > 100 | 112 | 875 | 100.0 |
| 120.0 | 100.0 | 17 | 120.0 | > 5000 | 5270 | 987 | 100.0 |
| 115.0 | 100.0 | 18 | 115.2 | > 60000 | 60947 | 223 | 100.1 |

Test results are graphically represented at following pages.




Power Recovery time


| 时间 [s] | A | B | 间隔 |
|---------------------|----------|----------|-----------|
| ● U1_tRMS_rc@AC [V] | 288.0327 | 230.0752 | -57.95744 |
| ● I1_tRMS_rc@AC [A] | 0.071718 | 3.489628 | 3.417910 |
| ● P_t_rc@AC [W] | 5.845e-3 | 800.0930 | 800.0871 |
| ● Q_t_rc@AC [var] | 20.65719 | 66.80357 | 46.14638 |
| ● S_t_rc@AC [VA] | 20.65719 | 802.8770 | 782.2198 |

L-N fault


Partial load (100%Pn)

Residual voltage: 120.0%Un

Voltage Rise time



| 时间 [s] | A | B | 间隔 |
|---------------------|----------|----------|-----------|
| ● U1_tRMS_rc@AC [V] | 230.0755 | 276.1056 | 46.03009 |
| ● I1_tRMS_rc@AC [A] | 3.507266 | 1.395256 | -2.112010 |
| ● P_t_rc@AC [W] | 804.0944 | 171.5915 | -632.5029 |
| ● Q_t_rc@AC [var] | 67.66158 | 344.9127 | 277.2511 |
| ● S_t_rc@AC [VA] | 806.9361 | 385.2381 | -421.6980 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|---------------|---------------|------------|
| | 0:17.85264184 | 0:23.12311274 | 5.27047090 |
| U1_tRMS_rc@AC [V] | 276.1056 | 276.5182 | 0.412537 |
| I1_tRMS_rc@AC [A] | 1.395256 | 0.068361 | -1.326895 |
| P_t_rc@AC [W] | 171.5915 | -0.137717 | -171.7292 |
| Q_t_rc@AC [var] | 344.9127 | 18.90261 | -326.0101 |
| S_t_rc@AC [VA] | 385.2381 | 18.90311 | -366.3350 |

Power Recovery time




| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|-----------|
| | 0:23.1339344 | 0:24.1210249 | 0.9870905 |
| U1_tRMS_rc@AC [V] | 276.6277 | 230.0791 | -46.54858 |
| I1_tRMS_rc@AC [A] | 0.068536 | 3.469577 | 3.401041 |
| P_t_rc@AC [W] | -0.048042 | 795.3338 | 795.3818 |
| Q_t_rc@AC [var] | 18.95879 | 68.48844 | 49.52965 |
| S_t_rc@AC [VA] | 18.95885 | 798.2772 | 779.3184 |

L-N fault

Partial load (100%Pn)


Residual voltage: 115.0%Un

Voltage Rise time




| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|-----------|
| 0:19.0576578 | 0:19.0758681 | 0:19.0758681 | 0.0182102 |
| U1_tRMS_rc@AC [V] | 230.0294 | 264.9280 | 34.89862 |
| I1_tRMS_rc@AC [A] | 3.466322 | 1.742890 | -1.723433 |
| P_t_rc@AC [W] | 794.0464 | 246.6007 | -547.4457 |
| Q_t_rc@AC [var] | 72.57177 | 390.3744 | 317.8026 |
| S_t_rc@AC [VA] | 797.3559 | 461.7403 | -335.6156 |

DipTime



| 时间 [s] | A | B | 间隔 |
|-------------------|--------------|--------------|--------------|
| 0:19.0765306 | 1:20.0231015 | 1:20.0231015 | 1:00.9465709 |
| U1_tRMS_rc@AC [V] | 264.9280 | 264.4584 | -0.469543 |
| I1_tRMS_rc@AC [A] | 1.742890 | 0.066391 | -1.676498 |
| P_t_rc@AC [W] | 246.6007 | -0.031662 | -246.6324 |
| Q_t_rc@AC [var] | 390.3744 | 17.55773 | -372.8166 |
| S_t_rc@AC [VA] | 461.7403 | 17.55776 | -444.1825 |

Power Recovery time



| 时间 [s] | A | B | 间隔 |
|---------------------|-----------|----------|-----------|
| ● U1_tRMS_rc@AC [V] | 264.4560 | 230.3006 | -34.15543 |
| ● I1_tRMS_rc@AC [A] | 0.066040 | 3.479489 | 3.413449 |
| ● P_t_rc@AC [W] | -7.800e-3 | 798.3892 | 798.3970 |
| ● Q_t_rc@AC [var] | 17.46477 | 68.56969 | 51.10492 |
| ● S_t_rc@AC [VA] | 17.46477 | 801.3284 | 783.8636 |

4.3. ACTIVE RESPONSE TO FREQUENCY DEVIATION

4.3.1. Power response to overfrequency

The test has been performed according to the clause 4.6.1 of the standard. The following definitions apply to the test to verify the clause:

- Test 1: P = 100 %P_n; f1 = 50.2 Hz; droop = 12 %; f-stop deactivated, with delay of 2 s ⁽¹⁾
- Test 2: P = 100 %; f1 = 52.0 Hz; droop = 2 %; function deactivated
- Test 3: P = 50 %; f1 = 51.0 Hz; droop = 5 %; f-stop deactivated, no delay
- Test 4: P = 100 %, f1 = 50.2 Hz; droop = 5 %; f-stop = 50.1 Hz (hysteresis), no delay

⁽¹⁾ The intentional delay is only active for the activation of the function, once the function is operating, the established control loop is not intentionally delayed.


Note:

Threshold for disconnection overfrequency protection is set at 52.0 Hz at each test items.

Test results are offered at the table below.


| Test 1 | | | | | |
|--|-----------------|-----------------|----------------------|---------------|----------------------------------|
| Step | Frequency (Hz) | P desired (%Pn) | Frequency meas. (Hz) | P meas. (%Pn) | P deviation (%Pn) (within ±10 %) |
| 1 | 50.00 ± 0.05 Hz | 100.0 | 50.00 | 99.9 | -0.1 |
| 2 | 50.20 ± 0.05 Hz | 100.0 | 50.20 | 99.8 | -0.2 |
| 3 | 51.00 ± 0.05 Hz | 86.7 | 51.00 | 86.7 | 0.0 |
| 4 | 51.80 ± 0.05 Hz | 73.3 | 51.80 | 74.5 | +1.2 |
| 5 | 50.20 ± 0.05 Hz | 100.0 | 50.20 | 99.8 | -0.2 |
| 6 | 50.00 ± 0.05 Hz | 100.0 | 50.00 | 100.0 | 0.0 |
| Time delay setting from step 2 to step 3 | | | | | |
| Time reference of change (s) | | | 360.2 | | |
| End of delay (s) | | | 363.4 | | |
| Delay time (s) | | | 3.2 | | |
| End of change (s) | | | 364.4 | | |
| Change time (s) | | | 1.0 | | |

Test results are represented at diagrams below.




| Test 2 | | | | | |
|--------|---------------------|-----------------|----------------------|---------------|--|
| Step | f (Hz) | P desired (%Pn) | Frequency meas. (Hz) | P meas. (%Pn) | P deviation (%Pn) (within $\pm 10\%$) |
| 1 | 50.00 \pm 0.05 Hz | 100.0 | 50.00 | 99.8 | -0.2 |
| 2 | 50.50 \pm 0.05 Hz | 100.0 | 50.50 | 99.3 | -0.7 |
| 3 | 51.00 \pm 0.05 Hz | 100.0 | 51.00 | 99.5 | -0.5 |
| 4 | 51.50 \pm 0.05 Hz | 100.0 | 51.50 | 99.5 | -0.5 |
| 5 | 51.80 \pm 0.05 Hz | 100.0 | 51.80 | 99.4 | -0.6 |
| 6 | 52.20 \pm 0.05 Hz | 0.0 | 52.20 | 0.0 | 0.0 |

Test results are represented at diagrams below.




| Test 3 | | | | | |
|--|-----------------|-----------------|----------------------|---------------|----------------------------------|
| Step | Frequency (Hz) | P desired (%Pn) | Frequency meas. (Hz) | P meas. (%Pn) | P deviation (%Pn) (within ±10 %) |
| 1 | 50.00 ± 0.05 Hz | 50.0 | 50.00 | 50.1 | +0.1 |
| 2 | 51.00 ± 0.05 Hz | 50.0 | 51.00 | 49.9 | -0.1 |
| 3 | 51.20 ± 0.05 Hz | 46.0 | 51.20 | 45.9 | -0.1 |
| 4 | 51.70 ± 0.05 Hz | 36.0 | 51.70 | 36.0 | 0.0 |
| 5 | 51.30 ± 0.05 Hz | 44.0 | 51.30 | 43.9 | -0.1 |
| 6 | 51.00 ± 0.05 Hz | 50.0 | 51.00 | 49.9 | -0.1 |
| 7 | 50.00 ± 0.05 Hz | 50.0 | 50.00 | 50.0 | 0.0 |
| Time delay setting from step 2 to step 3 | | | | | |
| Time reference of change (s) | | | 598.0 | | |
| End of delay (s) | | | 598.4 | | |
| Delay time (s) | | | 0.4 | | |
| End of change (s) | | | 598.8 | | |
| Change time (s) | | | 0.4 | | |

Test results are represented at diagrams below.



| Test 4 | | | | | |
|--|-----------------|-----------------|----------------------|---------------|----------------------------------|
| Step | Frequency (Hz) | P desired (%Pn) | Frequency meas. (Hz) | P meas. (%Pn) | P deviation (%Pn) (within ±10 %) |
| 1 | 50.00 ± 0.05 Hz | 100.0 | 50.00 | 99.8 | -0.2 |
| 2 | 50.20 ± 0.05 Hz | 100.0 | 50.20 | 99.7 | -0.3 |
| 3 | 51.00 ± 0.05 Hz | 68.0 | 51.00 | 68.2 | +0.2 |
| 4 | 50.30 ± 0.05 Hz | 68.0 | 50.30 | 68.0 | 0.0 |
| 5 | 51.00 ± 0.05 Hz | 68.0 | 51.00 | 68.2 | +0.2 |
| 6 | 52.00 ± 0.05 Hz | 28.0 | 52.00 | 28.3 | +0.3 |
| 7 | 51.00 ± 0.05 Hz | 28.0 | 51.00 | 28.5 | +0.5 |
| 8 | 50.50 ± 0.05 Hz | 28.0 | 50.50 | 28.5 | +0.5 |
| 9 | 50.20 ± 0.05 Hz | 28.0 | 50.20 | 28.4 | +0.4 |
| 10 | 50.00 ± 0.05 Hz | 100.0 | 50.00 | 99.8 | -0.2 |
| Time delay setting from step 2 to step 3 | | | | | |
| Time reference of change (s) | | | 241.2 | | |
| End of delay (s) | | | 241.8 | | |
| Delay time (s) | | | 0.6 | | |
| End of change (s) | | | 242.2 | | |
| Change time (s) | | | 0.4 | | |
| Recovery Time (s) | | | 379.4 | | |
| Power ramp gradient (%Pn/min) | | | 7.8 | | |

Test results are represented at diagrams below.



4.3.2. Power response to underfrequency

This test has not been performed to show the capability of the inverter, because it is only mandatory for Energy Storage Systems according to the clause 4.6.2 of the standard.

4.4. POWER RESPONSE TO VOLTAGE CHANGES

The generating unit shall be capable of operating in the control modes specified below within the limits specified in 4.7.2.2. The control modes are exclusive, only one mode may be active at a time.

- Q setpoint mode
- Q (U)
- Cos φ setpoint mode
- Cos φ (P)

4.4.1. Setpoint control modes

The test has been performed according to the clause 4.7.2.3.2 of the standard. The following definitions apply to the test to verify the clause:

- Test 1: Q Zero ($Q = 0 \% P_D$)
- Test 2: Rectangular Curve ($Q = \pm 43.6\% S_n = \pm 48.4\% P_D$)
- Test 3: Triangular Curve ($PF = \pm 0.8$)
- Test 4: Reactive power capability at active power P_D in the voltage range ($0.85U_n \sim 1.1U_n$)

4.4.1.1. Test 1: Q Zero (Q = 0 % P_D)

This test verifies the capability of the inverter to provide a fixed value of reactive power. In addition, it is verified the Q control mode.

When the measurement is equal to or greater than 10% S_n, the allowable tolerance of reactive power measurement should be within $\pm 2\%$ S_{max} or $\pm 2.2\%$ P_D.


Test results are offered at tables below.

| Rectangular Curve (Q=0% P _D) | | | | | |
|--|-------------------------------|------------------------------|-------------------------------|--|-------------------------------|
| P Desired (%S _n) | P measured (%S _n) | Q desired (%P _D) | Q measured (%P _D) | Q deviation ($\pm 2.2\%$ P _D) | Power Factor (cos φ) |
| 0.0 | 0.0 | -- | +0.5 | -- ⁽¹⁾ | -- |
| 10.0 | 9.8 | 0.0 | +0.4 | +0.4 | 0.999 |
| 20.0 | 19.6 | 0.0 | +0.4 | +0.4 | 1.000 |
| 30.0 | 29.7 | 0.0 | +0.4 | +0.4 | 1.000 |
| 40.0 | 39.5 | 0.0 | +0.4 | +0.4 | 1.000 |
| 50.0 | 49.5 | 0.0 | +0.4 | +0.4 | 1.000 |
| 60.0 | 60.5 | 0.0 | +0.4 | +0.4 | 1.000 |
| 70.0 | 70.5 | 0.0 | +0.4 | +0.4 | 1.000 |
| 80.0 | 80.3 | 0.0 | +0.4 | +0.4 | 1.000 |
| 90.0 | 90.2 | 0.0 | +0.4 | +0.4 | 1.000 |
| 100.0 | 100.1 | 0.0 | +0.4 | +0.4 | 1.000 |

⁽¹⁾ The reactive power accuracy is $\pm 2\%$ S_{max}, which is not suitable for power below 10% P_n.

Note: P_n is with respect to S_n , Q_n is according to measured PD ≈ 0.9 P_n (720 W)

Test results are represented at diagrams below.



4.4.1.2. Test 2: Rectangular Curve ($Q = \pm 43.6\%S_n = \pm 48.4\%P_D$)

This test verifies the capability of the inverter to provide a fixed value of reactive power. In addition, it is verified the Q control mode.

When the measurement is equal to or greater than 10% S_n , the allowable tolerance of reactive power measurement should be within $\pm 2\% S_{max}$ or $\pm 2.2\% P_D$.

Test results are offered at tables below.

| Rectangular Curve ($Q=48.4\%P_D$ / Capacitive) | | | | | |
|---|-----------------------|----------------------|-----------------------|--------------------------------|---------------------------------|
| P Desired (% S_n) | P measured (% S_n) | Q desired (% P_D) | Q measured (% P_D) | Q Deviation ($\pm 2.2\%P_D$) | Power Factor ($\cos \varphi$) |
| 0 | 0.1 | -- ⁽¹⁾ | -48.7 | -- ⁽¹⁾ | 0.001 |
| 10 | 10.7 | -48.4 | -48.7 | -0.3 | 0.215 |
| 20 | 20.4 | -48.4 | -48.7 | -0.3 | 0.389 |
| 30 | 30.4 | -48.4 | -48.7 | -0.3 | 0.532 |
| 40 | 40.3 | -48.4 | -48.7 | -0.3 | 0.640 |
| 50 | 50.3 | -48.4 | -48.7 | -0.3 | 0.721 |
| 60 | 60.3 | -48.4 | -48.7 | -0.3 | 0.780 |
| 70 | 70.1 | -48.4 | -48.7 | -0.3 | 0.823 |
| 80 | 80.0 | -48.4 | -48.7 | -0.3 | 0.856 |
| 90 | 90.2 | -48.4 | -48.7 | -0.3 | 0.899 |
| 100 | 90.2 ⁽²⁾ | -48.4 | -48.7 | -0.3 | 0.899 |

| Rectangular Curve ($Q=48.4\%P_D$ / Inductive) | | | | | |
|--|-----------------------|----------------------|-----------------------|--------------------------------|---------------------------------|
| P Desired (% S_n) | P measured (% S_n) | Q desired (% P_D) | Q measured (% P_D) | Q Deviation ($\pm 2.2\%P_D$) | Power Factor ($\cos \varphi$) |
| 0 | 0.1 | -- ⁽¹⁾ | +48.4 | -- ⁽¹⁾ | 0.002 |
| 10 | 10.7 | +48.4 | +48.4 | 0.0 | 0.238 |
| 20 | 20.4 | +48.4 | +48.4 | 0.0 | 0.424 |
| 30 | 30.4 | +48.4 | +48.4 | 0.0 | 0.572 |
| 40 | 40.3 | +48.4 | +48.4 | 0.0 | 0.679 |
| 50 | 50.3 | +48.4 | +48.4 | 0.0 | 0.756 |
| 60 | 60.2 | +48.4 | +48.4 | 0.0 | 0.810 |
| 70 | 70.1 | +48.4 | +48.4 | 0.0 | 0.849 |
| 80 | 80.0 | +48.4 | +48.4 | 0.0 | 0.878 |
| 90 | 90.0 | +48.4 | +48.4 | 0.0 | 0.900 |
| 100 | 90.0 ⁽²⁾ | +48.4 | +48.4 | 0.0 | 0.900 |


⁽¹⁾ The reactive power accuracy is $\pm 2.2\%P_D$, which is not suitable for power below 10% S_n .

⁽²⁾ Test performed in reactive power priority mode. Working in this mode, the inverter can't output the desired active power due to current limitation, so don't consider the deviation value.


Note: P_n is with respect to S_n , Q_n is according to measured $P_D \approx 0.9 P_n$ (720 W)

Test results are represented at diagrams below.

Supplementary information: p.u. values for P and S are given in reference to Sn, p.u. values for Q are given in reference to PD.



Rectangular Curve (Capacitive vs Inductive)



4.4.1.3. Test 3: Triangular Curve (PF = ±0.8)

This test verifies the capability of the inverter to provide a fixed value of power factor. In addition, it is verified the PF control mode.

When the measurement is equal to or greater than 10% Sn, the allowable tolerance of reactive power measurement should be within ±2% Smax.

Test results are offered at the tables below.

| Triangular Curve (PF = 0.8 / Capacitive) | | | | | | |
|--|---------------------|------------------|--------------------------------|---------------------|-------------------------------|--------------------------------|
| P desired (%Sn) | P measured (%Sn) | Q measured (%Sn) | Q desired (%Sn) ⁽³⁾ | Q deviation (±2%Sn) | Power factor measured (cos φ) | Power factor deviation (cos φ) |
| 0 | 0.0 | 0.0 | 0.0 | -- ⁽¹⁾ | -- ⁽¹⁾ | -- ⁽¹⁾ |
| 10 | 9.8 | -7.5 | -7.5 | +0.0 | 0.798 | -0.002 |
| 20 | 19.7 | -15.1 | -15.0 | +0.1 | 0.798 | -0.002 |
| 30 | 29.7 | -22.6 | -22.5 | +0.1 | 0.798 | -0.002 |
| 40 | 39.5 | -30.0 | -30.0 | +0.0 | 0.798 | -0.002 |
| 50 | 49.6 | -37.6 | -37.5 | +0.1 | 0.798 | -0.002 |
| 60 | 59.6 | -45.1 | -45.0 | +0.1 | 0.798 | -0.002 |
| 70 | 70.5 | -52.5 | -52.5 | +0.0 | 0.798 | -0.002 |
| 80 | 80.2 | -60.0 | -60.0 | +0.0 | 0.798 | -0.002 |
| 90 | 80.3 ⁽²⁾ | -60.0 | -67.5 | -- ⁽²⁾ | 0.798 | -0.002 |
| 100 | 80.3 ⁽²⁾ | -60.0 | -75.0 | -- ⁽²⁾ | 0.798 | -0.002 |


| Triangular Curve (PF = 0.8 / Inductive) | | | | | | |
|---|---------------------|------------------|--------------------------------|---------------------|-------------------------------|--------------------------------|
| P desired (%Sn) | P measured (%Sn) | Q measured (%Sn) | Q desired (%Sn) ⁽³⁾ | Q deviation (±2%Sn) | Power factor measured (cos φ) | Power factor deviation (cos φ) |
| 0 | 0.0 | 0.4 | 0.0 | -- ⁽¹⁾ | -- ⁽¹⁾ | -- ⁽¹⁾ |
| 10 | 9.8 | +7.4 | +7.5 | -0.1 | 0.799 | -0.001 |
| 20 | 19.7 | +14.8 | +15.0 | -0.2 | 0.799 | -0.001 |
| 30 | 29.7 | +22.3 | +22.5 | -0.2 | 0.799 | -0.001 |
| 40 | 39.5 | +29.7 | +30.0 | -0.3 | 0.799 | -0.001 |
| 50 | 49.6 | +37.3 | +37.5 | -0.2 | 0.799 | -0.001 |
| 60 | 59.7 | +44.9 | +45.0 | -0.1 | 0.799 | -0.001 |
| 70 | 69.4 | +52.3 | +52.5 | -0.2 | 0.799 | -0.001 |
| 80 | 79.4 | +59.7 | +60.0 | -0.3 | 0.799 | -0.001 |
| 90 | 80.3 ⁽²⁾ | +60.4 | +67.5 | -- ⁽²⁾ | 0.799 | -0.001 |
| 100 | 80.3 ⁽²⁾ | +60.5 | +75.0 | -- ⁽²⁾ | 0.799 | -0.001 |

⁽¹⁾ The reactive power accuracy is ±2%Sn, which is not suitable for power below 10%Sn.


⁽²⁾ Test performed in reactive power priority mode. Working in this mode, the inverter can't output the desired active power due to current limitation, so don't consider the deviation value.

⁽³⁾ Q desired value is calculated from the desired power and fixed power factor (PF = 0.8).

Test results are represented at the diagrams below.



Triangular Curve (Inductive vs Capacitive)



4.4.1.4. Test 4: Reactive power capability at active power P_D in the voltage range (0.85Un~1.1Un)

This test verifies the capability of the inverter to provide reactive power capability at active power P_D in the voltage range, as the Figure 13 of standard:




Figure 13 — Reactive power capability at active power P_D in the voltage range (positive sequence component of the fundamental)

Allowed tolerance for reactive power measurements is to be considered inside $\pm 2\% S_n$ or $\pm 2.2\% P_D$


Test results are offered at the tables below.

| Reactive power capability at active power P_D in the voltage range | | | | | | | | |
|--|------------------------|----------------------|----------------------|---------------------|--------------------|----------------------|---------------------------------|---------------------------------------|
| Step | Voltage desired (p.u.) | Voltage meas. (p.u.) | P desired (% S_n) | P meas. (% S_n) | Q meas. (% P_D) | Q desired (% P_D) | Q deviation ($\pm 2.2\% P_D$) | Power Factor measured ($\cos \phi$) |
| 1 | 1.100 | 1.100 | 90.0 | 90.1 | -48.5 | -48.4 | -0.1 | 0.900 |
| 2 | 1.100 | 1.100 | 90.0 | 90.1 | +1.5 | 0.0 | +1.5 | 1.000 |
| 3 | 1.050 | 1.050 | 90.0 | 89.9 | +48.2 | +48.4 | -0.2 | 0.901 |
| 4 | 1.000 | 1.000 | 90.0 | 90.2 | +48.2 | +48.4 | -0.2 | 0.901 |
| 5 | 0.900 | 0.900 | 90.0 | 80.8 ⁽¹⁾ | +43.6 | +43.6 | -0.0 | 0.900 |
| 6 | 0.850 | 0.850 | 90.0 | 76.3 ⁽¹⁾ | +41.1 | +41.2 | -0.1 | 0.900 |
| 7 | 0.850 | 0.850 | 90.0 | 85.2 ⁽¹⁾ | +2.0 | 0.0 | +2.0 | 1.000 |
| 8 | 0.900 | 0.900 | 90.0 | 89.8 | +2.0 | 0.0 | +2.0 | 1.000 |
| 9 | 0.950 | 0.950 | 90.0 | 84.3 | -48.3 | -48.4 | +0.1 | 0.889 |
| 10 | 1.000 | 1.000 | 90.0 | 89.5 | -48.3 | -48.4 | +0.1 | 0.899 |
| 11 | 1.050 | 1.050 | 90.0 | 90.4 | -48.3 | -48.4 | +0.1 | 0.901 |
| 12 | 1.100 | 1.100 | 90.0 | 89.8 | -48.3 | -48.4 | +0.1 | 0.900 |

⁽¹⁾ Since the working mode is reactive power priority, the active power cannot reach the expected value due to current limitation.

Note: P_n is with respect to S_n , Q_n is according to measured $P_D \approx 0.9 P_n$ (720 W)

Test results are represented at diagrams below.



4.4.2. Voltage related control mode

4.4.2.1. Voltage related control mode Q(U)

The test has been performed according to the clause 4.7.2.3.3 of the standard.

Note: This feature is optional, enabling and disabling the feature and its settings can be modified or adjusted through the manufacturer's guidelines.

Setting the characteristic as following to prove configurability of the inverter:

- $U_1 = 0.93$, $Q_{\max} = 43.6\%P_n = 48.4\%P_D$
- $U_2 = 0.96$, $Q = 9.0\%P_n = 10.0\%P_D$
- $U_3 = 1.04$, $Q = -9.0\%P_n = -10.0\%P_D$
- $U_4 = 1.07$, $-Q_{\max} = -43.6\%P_n = -48.4\%P_D$




Figure 16 — Example characteristics for Q respectively $\cos \varphi$ control mode



Test results are offered at the tables below.

| Undervoltage Test | | | | | | |
|-------------------|------------|------------------|-------------------|-------------------------------|------------------------------|----------------------------------|
| P/Pn setpoint (%) | U setpoint | P measured (%Sn) | V measured (p.u.) | Q measured (%P _D) | Q desired (%P _D) | ΔQ (p.u.) (±2.2%P _D) |
| 50 | 1.000 Un | 50.7 | 1.000 | +0.0 | 0.0 | +0.0 |
| 50 | 0.990 Un | 50.8 | 0.990 | +2.5 | +2.5 | +0.0 |
| 50 | 0.980 Un | 50.8 | 0.980 | +5.0 | +5.0 | -0.0 |
| 50 | 0.970 Un | 50.9 | 0.970 | +7.5 | +7.5 | +0.0 |
| 50 | 0.960 Un | 51.0 | 0.960 | +10.0 | +10.0 | -0.0 |
| 50 | 0.950 Un | 51.1 | 0.950 | +22.8 | +22.8 | +0.0 |
| 50 | 0.940 Un | 51.2 | 0.940 | +35.6 | +35.6 | +0.0 |
| 50 | 0.930 Un | 51.2 | 0.930 | +48.2 | +48.4 | -0.2 |
| 50 | 0.920 Un | 51.3 | 0.920 | +48.2 | +48.4 | -0.2 |
| 50 | 0.910 Un | 51.4 | 0.910 | +48.2 | +48.4 | -0.2 |
| 50 | 0.900 Un | 51.5 | 0.900 | +48.2 | +48.4 | -0.2 |
| 50 | 0.950 Un | 51.1 | 0.950 | +22.8 | +22.8 | +0.0 |
| 50 | 1.000 Un | 50.7 | 1.000 | +0.2 | 0.0 | +0.2 |


| Overvoltage Test | | | | | | |
|-------------------|------------|------------------|-------------------|-------------------------------|------------------------------|----------------------------------|
| P/Pn setpoint (%) | U setpoint | P measured (%Sn) | V measured (p.u.) | Q measured (%P _D) | Q desired (%P _D) | ΔQ (p.u.) (±2.2%P _D) |
| 50 | 1.000 Un | 49.9 | 1.000 | 0.0 | 0.0 | -0.0 |
| 50 | 1.010 Un | 49.6 | 1.010 | -2.5 | -2.5 | -0.0 |
| 50 | 1.020 Un | 49.5 | 1.020 | -5.0 | -5.0 | -0.0 |
| 50 | 1.030 Un | 49.4 | 1.030 | -7.5 | -7.5 | -0.0 |
| 50 | 1.040 Un | 49.3 | 1.040 | -10.0 | -10.0 | -0.0 |
| 50 | 1.050 Un | 49.3 | 1.050 | -22.8 | -22.8 | +0.0 |
| 50 | 1.060 Un | 49.2 | 1.060 | -35.6 | -35.6 | -0.0 |
| 50 | 1.070 Un | 49.7 | 1.070 | -48.2 | -48.4 | +0.2 |
| 50 | 1.080 Un | 49.0 | 1.080 | -48.3 | -48.4 | +0.1 |
| 50 | 1.090 Un | 48.9 | 1.090 | -48.3 | -48.4 | +0.1 |
| 50 | 1.100 Un | 48.8 | 1.100 | -48.3 | -48.4 | +0.1 |
| 50 | 1.050 Un | 49.3 | 1.050 | -22.8 | -22.8 | -0.0 |
| 50 | 1.000 Un | 49.8 | 1.000 | +0.3 | 0.0 | +0.3 |

Test results are represented at diagrams below.

Supplementary information: p.u. values for P and S are given in reference to S_n , p.u. values for Q are given in reference to P_D .



Voltage vs Reactive Power



4.4.2.2 Voltage related control mode Q(U) with lock-in/lock-out function

The test has been performed according to the clause 4.7.2.3.3 of the standard.

Two active power levels shall be configurable both at least in the range of 0 % to 100 % of P_D . The lock-in value turns the Q(U) mode on, the lock-out value turns Q(U) off. If lock-in is larger than lock-out a hysteresis is given. See also Figure 14 in the standard.




Figure 14 – Example of lock-in and lock-out values for Q(U) mode

Setting the characteristic as following to prove configurability of the inverter:

- U1 = 0.93, $Q_{max} = 43.6\%P_n = 48.4\%P_D$
 - U2 = 0.96, $Q = 9.0\%P_n = 10.0\%P_D$
 - U3 = 1.04, $Q = -9.0\%P_n = -10.0\%P_D$
 - U4 = 1.07, $-Q_{max} = -43.6\%P_n = -48.4\%P_D$
- P lock-in = $30\%P_n = 33.3\%P_D$, P lock-out = $20\%P_n = 22.2\%P_D$


Test results are offered at the tables below.

| Reactive power injection in relation with the Voltage (Inductive) | | | | | | |
|---|-------------------|---------------------|-------------------|-------------------------------|------------------------------|----------------------------------|
| P/Pn setpoint (%Pn) | U setpoint (p.u.) | P measured (%Sn) | V measured (p.u.) | Q measured (%P _D) | Q desired (%P _D) | ΔQ (p.u.) (±2.2%P _D) |
| <20.0 | 0.920 | 15.7 | 0.920 | +0.7 | 0.0 | +0.7 |
| 25.0 | 0.920 | 25.5 | 0.920 | +0.7 | 0.0 | +0.7 |
| 35.0 | 0.920 | 35.4 | 0.920 | +48.0 | +48.4 | -0.4 |
| 50.0 | 0.920 | 50.4 | 0.920 | +48.0 | +48.4 | -0.4 |
| 75.0 | 0.920 | 75.3 | 0.920 | +48.0 | +48.4 | -0.4 |
| 90.0 | 0.920 | 81.5 ⁽¹⁾ | 0.920 | +48.0 | +48.4 | -0.4 |
| 100.0 | 0.920 | 81.5 ⁽¹⁾ | 0.920 | +48.0 | +48.4 | -0.4 |
| 50.0 | 0.920 | 50.4 | 0.920 | +48.0 | +48.4 | -0.4 |
| 25.0 | 0.920 | 25.5 | 0.920 | +48.0 | +48.4 | -0.4 |
| <20.0 | 0.920 | 15.7 | 0.920 | +1.0 | 0.0 | +1.0 |
| 35.0 | 0.920 | 35.4 | 0.920 | +48.4 | +48.4 | 0.0 |
| 35.0 | 0.950 | 35.2 | 0.950 | +22.7 | +22.8 | -0.1 |
| 35.0 | 1.000 | 34.8 | 1.000 | +1.0 | 0.0 | +1.0 |

⁽¹⁾ Since the working mode is reactive power priority, the active power cannot reach the expected value due to current limitation.

Test results are represented at diagrams below.

Supplementary information: p.u. values for P and S are given in reference to S_n, p.u. values for Q are given in reference to P_D.




| Reactive power injection in relation with the Voltage (Capacitive) | | | | | | |
|--|-------------------|------------------|-------------------|-------------------------------|------------------------------|----------------------------------|
| P/Pn setpoint (%Pn) | U setpoint (p.u.) | P measured (%Sn) | V measured (p.u.) | Q measured (%P _D) | Q desired (%P _D) | ΔQ (p.u.) (±2.2%P _D) |
| <20.0 | 1.080 | 15.4 | 1.080 | -1.3 | 0.0 | -1.3 |
| 25.0 | 1.080 | 25.2 | 1.080 | -1.3 | 0.0 | -1.3 |
| 35.0 | 1.080 | 35.3 | 1.080 | -47.0 | -48.4 | +1.4 |
| 50.0 | 1.080 | 50.2 | 1.080 | -47.0 | -48.4 | +1.4 |
| 75.0 | 1.080 | 75.1 | 1.080 | -47.0 | -48.4 | +1.4 |
| 90.0 | 1.080 | 90.1 | 1.080 | -47.0 | -48.4 | +1.4 |
| 100.0 | 1.080 | 87.4 | 1.080 | -47.0 | -48.4 | +1.4 |
| 50.0 | 1.080 | 50.1 | 1.080 | -47.0 | -48.4 | +1.4 |
| 25.0 | 1.080 | 25.2 | 1.080 | -47.0 | -48.4 | +1.4 |
| <20.0 | 1.080 | 15.4 | 1.080 | -1.0 | 0.0 | -1.0 |
| 35.0 | 1.080 | 35.2 | 1.080 | -47.8 | -48.4 | +0.6 |
| 35.0 | 1.050 | 35.5 | 1.050 | -23.1 | -22.8 | -0.3 |
| 35.0 | 1.000 | 36.0 | 1.000 | -0.4 | 0.0 | -0.4 |

(1) Since the working mode is reactive power priority, the active power cannot reach the expected value due to current limitation.

Test results are represented at diagrams below.

Supplementary information: p.u. values for P and S are given in reference to S_n, p.u. values for Q are given in reference to P_D.



4.4.2.3 Static accuracy

The test has been performed according to the clause 4.7.2.3.3 of the standard.

The dynamics of the control shall correspond with a first order filter having a time constant that is configurable in the range of 3 s to 60 s.

The dynamic accuracy shall be in accordance with Figure 15 in the standard with a maximum tolerance of $\pm 5\%P_D$ plus a time delay of up to 3 seconds deviating from an ideal first order filter response.




Figure 15 — Example of dynamic control response and tolerance band for a step from $Q=0$ to $Q=33\%P_D$ with $\tau=3,33s$

Note: Figure 15 – Is from $Q=0$ to $Q=33\%P_D$.

The response time is adjustable from 2 s to 60s by settings, which is more stringent than the standard's requirement, from 3s to 60s.

Test results are offered at the tables below.


| Setting time = 2 s | | | | |
|--------------------|---|-------------------|-------------------------------|--|
| %Pn | Steps | Time measured (s) | Q Measured (%P _D) | ΔQ (%S _n) < $\pm 2.2\%P_D$ |
| 50 | $Q = 0 \rightarrow Q = 33\%P_D$ (Inductive) | 11.0 | +33.0 | 0.0 |
| | $Q = 33\%P_D$ (Inductive) \rightarrow $Q = 33\%P_D$ (Capacitive) | 13.4 | -33.0 | 0.0 |
| | $Q = -33\%P_D$ (Capacitive) $\rightarrow Q = 0$ | 11.0 | +1.9 | +1.9 |

| Setting time = 60 s | | | | |
|---------------------|--|-------------------|-------------------------------|--|
| %Pn | Steps | Time measured (s) | Q Measured (%P _D) | ΔQ (%S _n) < $\pm 2.2\%P_D$ |
| 50 | $Q = 0 \rightarrow Q = 33\%S_n$ ($33\%P_D$)(Inductive) | 178.2 | +33.0 | 0.0 |
| | $Q = 33\%S_n$ ($33\%P_D$) (Inductive) \rightarrow $Q = -33\%S_n$ ($33\%P_D$) (Capacitive) | 228.2 | -33.0 | 0.0 |
| | $Q = -33\%S_n$ ($-33\%P_D$) (Capacitive) $\rightarrow Q = 0$ | 147.6 | +1.8 | +1.8 |


Test results are represented at diagrams below.

Supplementary information: p.u. values for P and S are given in reference to S_n, p.u. values for Q are given in reference to P_D.

Reactive power injection dynamic control response and tolerance band (Setting time = 2 s)



Reactive power injection dynamic control response and tolerance band (Setting time = 60 s)




4.4.2.4 Power related control mode

The test has been performed according to the clause 4.7.2.3.4 of the standard.

The power related control mode $\cos \varphi (P)$ controls the $\cos \varphi$ of the output as a function of the active power output.

For power related control modes, a characteristic defined by the manufacturer as follows:



Resulting from a change in active power output a new $\cos \varphi$ set point is defined according to the set characteristic. The response to a new $\cos \varphi$ set value shall be as fast as technically feasible to allow the change in reactive power to be in synchrony with the change in active power. The new reactive power set value shall be reached at the latest within 10 s after the end value of the active power is reached. The static accuracy of each $\cos \varphi$ set point shall be according to 4.7.2.2.



The results are offered in the table below (Note: 10 %P_n has not been measured in the following test):

| Setting $\cos \varphi(P)$ with the standard characteristic curve (20 %P _D to 100 %P _D) | | | | | | | |
|---|--|--|-------------------------|------------------------|------------------------------|---|-------------------------|
| Active Power setting (%P _D) | Active Power measured (%P _D) | Reactive Power measured (%P _D) | $\cos \varphi$ measured | Desired $\cos \varphi$ | Desired Q (%P _D) | ΔQ (%P _D) (± 2.2) | Transient period (<10s) |
| 20 | 20.3 | -1.0 | 0.999 | 1.000 | 0.0 | -1.0 | --- |
| 30 | 30.1 | -1.2 | 0.999 | 1.000 | 0.0 | -1.2 | -- |
| 40 | 40.0 | -1.3 | 0.999 | 1.000 | 0.0 | -1.3 | -- |
| 50 | 50.0 | -1.3 | 0.999 | 1.000 | 0.0 | -1.3 | -- |
| 60 | 60.0 | -12.7 | 0.978 | 0.980 | -12.2 | -0.5 | 3.60 |
| 70 | 69.9 | -20.9 | 0.958 | 0.960 | -20.4 | -0.5 | 2.40 |
| 80 | 79.8 | -29.5 | 0.938 | 0.940 | -29.0 | -0.5 | 3.20 |
| 90 | 89.6 | -38.7 | 0.918 | 0.920 | -38.3 | -0.4 | 1.80 |
| 100 | 99.4 | -48.1 | 0.900 | 0.900 | -48.4 | +0.3 | 1.20 |

Note: The desired Q is calculated from $Q = -\sqrt{(S^2 - P^2)}$.

Test results are represented at diagrams below.

Setting $\cos \phi(P)$ with standard characteristic curve (20 % P_D to 100 % P_D)




4.4.3. Voltage related active power reduction (Volt-Watt)

The test has been performed according to the clause 4.7.3 of the standard.

The final implemented logic can be chosen by the manufacturer. Nevertheless, this logic shall not cause steps or oscillations in the output power. The power reduction caused by such a function may not be faster than an equivalent of a time constant $\tau = 3 \text{ s}$ ($= 33 \text{ %/s}$ at a 100 % change).

The following parameters have been set by the manufacturer for this test:



Test 1 and Test 2 setpoint as following:

| Reference | Test 1 Set points | | Test 2 Set points | |
|-----------|-------------------|------------|-------------------|------------|
| | Volt.(%Un) | Power(%Pn) | Volt.(%Un) | Power(%Pn) |
| V1 | 90.0% | 100.0% | 90.0% | 100.0% |
| V2 | 95.6% | 100.0% | 95.6% | 100.0% |
| V3 | 104.0% | 100.0% | 108.7% | 100.0% |
| V4 | 110.0% | 20.0% | 115.2% | 20.0% |



Test results are offered at tables below.

| Volt-Watt TEST 1 | | | | | |
|------------------|----------------|------------------|----------------------|--------------------|-------------------|
| V setting (p.u.) | V meas. (p.u.) | P desired (p.u.) | P meas. (p.u.) | P deviation (p.u.) | Response time (s) |
| 0.900 | 0.900 | 1.000 | 0.905 ⁽¹⁾ | -- | -- |
| 0.950 | 0.950 | 1.000 | 0.956 ⁽¹⁾ | -- | -- |
| 1.000 | 1.000 | 1.000 | 1.006 | +0.006 | -- |
| 1.020 | 1.020 | 1.000 | 1.005 | +0.005 | -- |
| 1.040 | 1.040 | 1.000 | 1.003 | +0.003 | -- |
| 1.050 | 1.050 | 0.867 | 0.863 | -0.004 | 0.4 |
| 1.060 | 1.060 | 0.733 | 0.732 | -0.001 | 0.4 |
| 1.070 | 1.070 | 0.600 | 0.603 | +0.003 | 0.4 |
| 1.100 | 1.100 | 0.200 | 0.201 | +0.001 | 0.8 |

| Volt-Watt TEST 2 | | | | | |
|------------------|----------------|------------------|----------------------|--------------------|-------------------|
| V setting (p.u.) | V meas. (p.u.) | P desired (p.u.) | P meas. (p.u.) | P deviation (p.u.) | Response time (s) |
| 0.900 | 0.900 | 1.000 | 0.905 ⁽¹⁾ | -- | -- |
| 0.950 | 0.950 | 1.000 | 0.955 ⁽¹⁾ | -- | -- |
| 1.000 | 1.000 | 1.000 | 1.005 | +0.005 | -- |
| 1.020 | 1.020 | 1.000 | 1.004 | +0.004 | -- |
| 1.040 | 1.040 | 1.000 | 1.001 | +0.001 | -- |
| 1.050 | 1.050 | 1.000 | 1.001 | +0.001 | -- |
| 1.060 | 1.060 | 1.000 | 0.999 | -0.001 | -- |
| 1.070 | 1.070 | 1.000 | 0.999 | -0.001 | -- |
| 1.100 | 1.100 | 0.840 | 0.837 | -0.003 | 0.8 |
| 1.120 | 1.120 | 0.594 | 0.596 | +0.002 | 0.8 |
| 1.152 | 1.152 | 0.200 | 0.204 | +0.004 | 0.8 |

⁽¹⁾ The active power cannot reach the expected value due to current limitation.

Test results are represented at diagrams below.



4.4.4. Short circuit current requirements on generating plants

The tests of the chapter 4.7.4 of the standard describe the required short circuit current contribution for generating plants taking into account the connection technology of the generating modules.

These tests are considered optional for Type A and Type B generating units connected to LV distribution grids, thus they have not been performed.

4.4.4.1 Generating plant with non-synchronous generating technology

4.4.4.1.1 Voltage support during faults and voltage steps

The requirements are stated in clause 4.7.4.2.1 of the standard.

The EUT is classified as Type A and B. This is no voltage support during faults and voltage steps.

4.4.4.1.2 Zero current mode for converter connected generating technology

The requirements are stated in clause 4.7.4.2.2 of the standard.

The EUT is classified as Type A and B. Refer to Section 4.2.2 and 4.2.3 of this report. During UVRT and OVRT, the EUT is always work at zero current mode.

4.4.4.1.3 Induction generator based units

The requirements are stated in clause 4.7.4.2.3 of the standard.

In general, no voltage support during faults and voltage steps is required from generating plants connected in LV distribution networks as the additional reactive current is expected to interfere with grid protection equipment. This clause is not applicable.

4.4.4.2 Generating plant with synchronous generating technology - Synchronous generator based units

The requirements are stated in clause 4.7.4.3 of the standard.

The EUT is with non-synchronous generating technology. This clause is not applicable.

4.5. EMC AND POWER QUALITY

As required in clause 4.8 of the standard, all electric and electronic equipment to be installed under the scope of this standard shall be in compliance with relative standards for Electromagnetic Compatibility.

The compliances with these requirements are stated in the following EMC test reports:

EN IEC 61000-6-3: 2021; EN IEC 61000-6-1: 2019: Test Report no. GZCR231100125005C02 , issued by SGS-SCTS Standards Technical Services Co., Ltd. Guangzhou Branch, on May 28 of 2024. NVLAP LAB CODE 200611-0.

Note: Aside of EMC evidence of compliances, the harmonic and flicker content has been measured just to provide further information of the tested unit, and the results are stated in the following items 4.5.1 and 4.5.2 of the report.


4.5.1. Harmonic emissions

The test has been performed according to the clause 4.8 of the standard EN 61000-3-2:2011-05.

Below are the measured values of current harmonics.

| Pn (%) | 33 | | | Limit (A) |
|----------------|--------------------|--------------------|--------------------|-----------|
| | 33 | 66 | 100 | |
| Nr./Order | I _h (A) | I _h (A) | I _h (A) | |
| 2 | 0.021 | 0.038 | 0.059 | 1.080 |
| 3 | 0.041 | 0.133 | 0.230 | 2.300 |
| 4 | 0.009 | 0.015 | 0.024 | 0.430 |
| 5 | 0.018 | 0.075 | 0.127 | 1.140 |
| 6 | 0.006 | 0.011 | 0.018 | 0.300 |
| 7 | 0.014 | 0.067 | 0.101 | 0.770 |
| 8 | 0.005 | 0.009 | 0.014 | 1.000 |
| 9 | 0.018 | 0.051 | 0.079 | 0.400 |
| 10 | 0.004 | 0.007 | 0.011 | 0.800 |
| 11 | 0.023 | 0.032 | 0.049 | 0.330 |
| 12 | 0.003 | 0.005 | 0.010 | 0.667 |
| 13 | 0.021 | 0.022 | 0.027 | 0.210 |
| 14 | 0.003 | 0.006 | 0.009 | 0.571 |
| 15 | 0.013 | 0.010 | 0.011 | 1.000 |
| 16 | 0.003 | 0.006 | 0.008 | 0.500 |
| 17 | 0.005 | 0.003 | 0.003 | 0.882 |
| 18 | 0.003 | 0.005 | 0.007 | 0.444 |
| 19 | 0.003 | 0.008 | 0.009 | 0.789 |
| 20 | 0.003 | 0.004 | 0.006 | 0.400 |
| 21 | 0.004 | 0.007 | 0.009 | 0.714 |
| 22 | 0.003 | 0.003 | 0.005 | 0.364 |
| 23 | 0.006 | 0.004 | 0.006 | 0.652 |
| 24 | 0.002 | 0.003 | 0.004 | 0.333 |
| 25 | 0.008 | 0.002 | 0.002 | 0.600 |
| 26 | 0.002 | 0.003 | 0.003 | 0.308 |
| 27 | 0.006 | 0.002 | 0.002 | 0.556 |
| 28 | 0.002 | 0.004 | 0.003 | 0.286 |
| 29 | 0.004 | 0.004 | 0.003 | 0.517 |
| 30 | 0.002 | 0.002 | 0.002 | 0.267 |
| 31 | 0.001 | 0.003 | 0.002 | 0.484 |
| 32 | 0.003 | 0.002 | 0.003 | 0.250 |
| 33 | 0.001 | 0.003 | 0.003 | 0.455 |
| 34 | 0.002 | 0.003 | 0.004 | 0.235 |
| 35 | 0.002 | 0.003 | 0.005 | 0.429 |
| 36 | 0.001 | 0.003 | 0.003 | 0.222 |
| 37 | 0.003 | 0.003 | 0.004 | 0.405 |
| 38 | 0.001 | 0.003 | 0.002 | 0.211 |
| 39 | 0.003 | 0.004 | 0.004 | 0.385 |
| 40 | 0.001 | 0.002 | 0.003 | 0.200 |
| THD (%) | 5.900 | 8.073 | 8.765 | 13.000 |
| PWHD(%) | 8.626 | 4.561 | 3.611 | 22.000 |

Test results are represented at diagrams below.



4.5.2. Flicker and voltage fluctuations

The test has been performed according to the clause 4.8 of the standard.

The measurements of voltage fluctuations have been measured at 33%, 66% and 100% of the nominal power value of the inverter according to the standard IEC 61000-3-3:2017.

The flicker test result as following:

| 33 %Pn | | |
|-----------------|---------|-------|
| Item | Limit | L-N |
| P _{ST} | ≤ 1.000 | 0.133 |
| P _{LT} | ≤ 0.650 | 0.058 |
| dc [%] | ≤ 3.300 | 0.000 |
| dmax [%] | 4.000 | 0.000 |

| 66 %Pn | | |
|-----------------|---------|-------|
| Item | Limit | L-N |
| P _{ST} | ≤ 1.000 | 0.015 |
| P _{LT} | ≤ 0.650 | 0.014 |
| dc [%] | ≤ 3.300 | 0.000 |
| dmax [%] | 4.000 | 0.000 |

| 100 %Pn | | |
|-----------------|---------|-------|
| Item | Limit | L-N |
| P _{ST} | ≤ 1.000 | 0.017 |
| P _{LT} | ≤ 0.650 | 0.017 |
| dc [%] | ≤ 3.300 | 0.000 |
| dmax [%] | 4.000 | 0.000 |

As it can be seen in the next screenshots, this test has 12 steps. The values took of Pst, Plt, dc and dmax are the most unfavorable of the 12 steps.

Test results are represented at diagrams below.

33 %Pn

L-N

Flicker Mode Range Over

Flicker U1 U2 U3 U4 U5 U6 U7

I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 600 V/50Hz Element1 Judgement Pass

Un (Set) 230.000V Total Judgement Pass

Freq (U1) 49.997Hz (Element1)

Dmin 0.10%

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|--------|------------|------------|--------------|------------|--------------|
| Limit | 1.10 | 1.10 | 200 3.00% | 3.20 | 3.10 N:12 |
| No. 1 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.133 Pass | |
| 2 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 3 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 4 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 5 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 6 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 7 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 8 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 9 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 10 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 11 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| 12 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.012 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.058 Pass |

Update: 3662
Runtime: 3:25:45

139% 10%
2024-04-02 18:06:52

- Element 1
U1 600 V
I1 25 A
Sync Src: U1
Integral: Reset
- Element 2
U2 300 V
I2 50 A
Sync Src: U2
Integral: Reset
- Element 3
U3 300 V
I3 50 A
Sync Src: U2
Integral: Reset
- Element 4
U4 600 V
I4 1 A
Sync Src: U1
Integral: Reset

66 %Pn

L-N

Flicker Mode Range Over

Flicker U1 U2 U3 U4 U5 U6 U7

I1 I2 I3 I4 I5 I6 I7

SCL Line Filter

AVG Freq Filter

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 600 V/50Hz Element1 Judgement Pass

Un (Set) 230.000V Total Judgement Pass

Freq (U1) 43.101Hz (Element1)

Dmin 0.10%

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|--------|------------|------------|--------------|------------|--------------|
| Limit | 1.10 | 1.10 | 200 3.00% | 3.20 | 3.10 N:12 |
| No. 1 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 2 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 3 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 4 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 5 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 6 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 7 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 8 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 9 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 10 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 11 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.014 Pass | |
| 12 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.015 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.014 Pass |

Update: 5262
Runtime: 2:57:24

137% 10%
2024-04-03 17:33:27

- Element 1
U1 600 V
I1 25 A
Sync Src: U1
Integral: Reset
- Element 2
U2 300 V
I2 50 A
Sync Src: U2
Integral: Reset
- Element 3
U3 300 V
I3 50 A
Sync Src: U2
Integral: Reset
- Element 4
U4 600 V
I4 1 A
Sync Src: U1
Integral: Reset

Member of the SGS Group (SGS SA)
TRF No. EEC_EN 50549-1 B

100 %Pn
L-N

Flicker Mode
Flicker

Range Over

| | | | | | | |
|----|----|----|----|----|----|----|
| U1 | U2 | U3 | U4 | U5 | U6 | U7 |
| I1 | I2 | I3 | I4 | I5 | I6 | I7 |

SCL Line Filter

AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 1

| | | | | |
|------------|------------|------------|-----------|------|
| Volt Range | 600 V/50Hz | Element1 | Judgement | Pass |
| Un (Set) | 230.000V | Total | Judgement | Pass |
| Freq (U1) | 49.997Hz | (Element1) | | |
| Dmin | 0.10% | | | |

| | dc[%] | dmax[%] | d(t)[ms] | Pst | Plt |
|--------|---|---|---|---|---|
| Limit | 1.10 | 1.10 | 200 3.00% | 3.20 | 3.10 N:12 |
| No. 1 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.016 Pass | |
| 2 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.016 Pass | |
| 3 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 4 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 5 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 6 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 7 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 8 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 9 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 10 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 11 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| 12 | 0.000 Pass | 0.000 Pass | 0.0 Pass | 0.017 Pass | |
| Result | Pass | Pass | Pass | Pass | 0.017 Pass |

Update: 3700

Runtime: 2:33:57

136%
10%
x2
2024-04-07
11:45:36

Element 1

U1 600 V

I1 25 A

Sync Src: U1

Integral: Reset

Element 2

U2 300 V

I2 50 A

Sync Src: U2

Integral: Reset

Element 3

U3 300 V

I3 50 A

Sync Src: U2

Integral: Reset

Element 4

U4 600 V

I4 1 A

Sync Src: U1

Integral: Reset

4.6. INTERFACE PROTECTION

4.6.1. Requirements on voltage and frequency protection

The test has been performed according to the clause 4.9.3 of the standard. The minimum required accuracy for protection is:

- For frequency measurement ± 0.05 Hz;
- For voltage measurement ± 1 %Un.
- The reset time shall be ≤ 50 ms.
- The interface protection relay shall not conduct continuous starting and disengaging operations of the interface protection relay. Therefore, a reasonable reset ratio shall be implemented which shall not be zero but be below 2 % of nominal value for voltage and below 0.2 Hz for frequency.

4.6.1.1 Undervoltage protection

Undervoltage protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.

Undervoltage threshold stage 1 [27 <]:

- Threshold (0.2 – 1.0) U_n adjustable by steps of 0.01 U_n
- Operate time (0.1 – 100) s adjustable in steps of 0.1 s

Undervoltage threshold stage 2 [27 <<]:



- Threshold (0.2 – 1.0) U_n adjustable by steps of 0.01 U_n
- Operate time (0.1 – 5) s adjustable in steps of 0.05 s

The undervoltage threshold stage 2 is not applicable for micro-generating plants.


The following definitions apply to the test to verify the clause:

| Undervoltage | Test No. | Voltage setting (p.u.) | Voltage meas. (p.u.) | Voltage deviation (p.u.) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|---------------------------|----------|------------------------|----------------------|--------------------------|-----------------------|---------------------|-------------------------|
| Stage 1 [27 <] | 1 | 0.200 | 0.204 | +0.004 | 100.000 | 99.900 | -0.100 |
| | 2 | 1.000 | 1.000 | +0.000 | 0.100 | 0.043 | -0.057 |
| Stage 2 [27 <<] | 3 | 0.200 | 0.200 | 0.000 | 5.000 | 4.980 | -0.020 |
| | 4 | 1.000 | 1.002 | +0.002 | 0.100 | 0.027 | -0.073 |


Test results are represented at diagrams below.




Under voltage - Test 2: Trip value




Under voltage - Test 2: Trip time




Under voltage - Test 3: Trip value




Under voltage - Test 3: Trip time



Under voltage - Test 4: Trip value



Under voltage - Test 4: Trip time



4.6.1.2 Overvoltage protection

Overvoltage protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.

Overvoltage threshold stage 1 [59 >]:

- Threshold (1.0 – 1.2) U_n adjustable by steps of 0.01 U_n
- Operate time (0.1 – 100) s adjustable in steps of 0.1 s



Overvoltage threshold stage 2 [59 > >]:

- Threshold (1.0 – 1.3) U_n adjustable by steps of 0.01 U_n
- Operate time (0.1 – 5) s adjustable in steps of 0.05 s


The following definitions apply to the test to verify the clause:

| Overvoltage | Test No. | Voltage setting (p.u.) | Voltage meas. (p.u.) | Voltage deviation (p.u.) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|-----------------------------|----------|------------------------|----------------------|--------------------------|-----------------------|---------------------|-------------------------|
| Stage 1 [59 >]: | 1 | 1.000 | 1.000 | 0.000 | 100.000 | 99.900 | -0.100 |
| | 2 | 1.200 | 1.200 | 0.000 | 0.100 | 0.026 | -0.074 |
| Stage 2 [59 > >]: | 3 | 1.000 | 1.000 | 0.000 | 5.000 | 4.980 | -0.020 |
| | 4 | 1.300 | 1.300 | 0.000 | 0.100 | 0.012 | -0.088 |


Test results are represented at diagrams below.




Overvoltage - Test 2: Trip value




Overvoltage - Test 2: Trip time




Overvoltage - Test 3: Trip value




Overvoltage - Test 3: Trip time



Overvoltage - Test 4: Trip value



Overvoltage - Test 4: Trip time



4.6.1.3 Overvoltage 10 min mean protection

The function shall be based on the calculation of the square root of the arithmetic mean of the squared input values over 10 min. The calculation of a new 10 min value at least every 3 s is sufficient, which is then to be compared with the threshold value.


- Threshold (1.0 – 1.15) U_n adjustable by steps of 0.01 U_n
- Start time ≤ 3 s not adjustable
- Time delay setting = 0 ms

The following definitions apply to the test to verify the clause:

| Test No. | Voltage setting (p.u.) | Voltage meas. (p.u.) | Voltage deviation (p.u.) | Trip time meas. (s) | Trip time limited |
|----------|------------------------|----------------------|--------------------------|---------------------|-------------------|
| 1 | 1.000 | 1.000 | 0.000 | 2.1 | ≤ 3.0 s |
| 2 | 1.150 | 1.150 | 0.000 | 1.6 | ≤ 3.0 s |

Remark: The trip voltage accuracy tolerance is $\pm 0.01 U_n$.

Test results are represented at diagrams below.



4.6.1.4 Underfrequency protection

Underfrequency protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.

Underfrequency threshold stage 1 [81 <]:

- Threshold (47.0 – 50.0) Hz adjustment by steps of 0.1 Hz
- Operate time (0.1 – 100) s adjustable in steps of 0.1 s

Underfrequency threshold stage 2 [81 <<]:

- Threshold (47.0 – 50.0) Hz adjustment by steps of 0.1 Hz
- Operate time (0.1 – 5) s adjustable in steps of 0.05 s

In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal.

The frequency protection shall function correctly in the input voltage range between 20 % U_n and 120 % U_n and shall be inhibited for input voltages of less than 20 % U_n .



Under 0.2 U_n the frequency protection is inhibited. Disconnection may only happen based on undervoltage protection.

The following definitions apply to the test to verify the clause:


| Under frequency | Test No. | Frequency setting (Hz) | Frequency meas. (Hz) | Frequency deviation (Hz) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|-----------------|----------|------------------------|----------------------|--------------------------|-----------------------|---------------------|-------------------------|
| Stage 1 [81 <] | 1 | 47.00 | 47.00 | 0.00 | 100.000 | 99.9 | -0.100 |
| | 2 | 50.00 | 50.00 | 0.00 | 0.100 | 0.040 | -0.060 |
| Stage 2 [81 <<] | 3 | 47.00 | 47.00 | 0.00 | 5.000 | 4.960 | -0.040 |
| | 4 | 50.00 | 50.00 | 0.00 | 0.100 | 0.039 | -0.061 |

| Voltage protection threshold setting (p.u.) | Test No. | Frequency setting (Hz) | Voltage setting (p.u.) | Trip value meas. (Hz) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|---|----------|------------------------|------------------------|-----------------------|-----------------------|---------------------|-------------------------|
| 0.18 & 1.22 | 5 | 47.00 | 0.210 | 47.00 | 5.000 | 4.940 | -0.060 |
| | 6 | 47.00 | 1.190 | 47.00 | 5.000 | 4.980 | -0.020 |
| | 7 | 47.00 | 0.190 | -- | Not protected | -- | -- |
| | | 47.00 | 0.170 | 47.00 | 5.000 | 4.920 | -0.080 |
| | 8 | 47.00 | 1.210 | -- | Not protected | -- | -- |
| | | 47.00 | 1.230 | 47.00 | 5.000 | 4.980 | -0.020 |


Test results are represented at diagrams below.




Underfrequency - Test 2: Trip value




Underfrequency - Test 2: Trip time




Underfrequency - Test 3: Trip value




Underfrequency - Test 3: Trip time




Underfrequency - Test 4: Trip value



Underfrequency - Test 4: Trip time




Underfrequency - Test 5: Trip value




Underfrequency - Test 5: Trip time




Underfrequency - Test 6: Trip value




Underfrequency - Test 6: Trip time




Underfrequency - Test 7: Trip value




Underfrequency - Test 7: Trip time



Underfrequency - Test 8: Trip value



Underfrequency - Test 8: Trip time



4.6.1.5 Overfrequency protection

Overfrequency protection may be implemented with two completely independent protection thresholds, each one able to be activated or not. The standard adjustment ranges are as follows.

Overfrequency threshold stage 1 [81 >]:

- Threshold (50.0 – 52.0) Hz adjustment by steps of 0.1 Hz
- Operate time (0.1 – 100) s adjustable in steps of 0.1 s

Overfrequency threshold stage 2 [81 > >]:

- Threshold (50.0 – 52.0) Hz adjustment by steps of 0.1 Hz
- Operate time (0.1 - 5) s adjustable in steps of 0.05 s

In order to use narrow frequency thresholds for islanding detection (see 4.9.3.3) it may be required to have the ability to activate and deactivate a stage by an external signal.



The frequency protection shall function correctly in the input voltage range between 20 %Un and 120 %Un and shall be inhibited for input voltages of less than 20 %Un.

The following definitions apply to the test to verify the clause:


| Over frequency | Test No. | Frequency setting (Hz) | Frequency meas. (Hz) | Frequency deviation (Hz) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|------------------|----------|------------------------|----------------------|--------------------------|-----------------------|---------------------|-------------------------|
| Stage 1 [81 >] | 1 | 50.00 | 50.00 | 0.00 | 100.000 | 99.900 | -0.100 |
| | 2 | 52.00 | 52.00 | 0.00 | 0.100 | 0.034 | -0.066 |
| Stage 2 [81 > >] | 3 | 50.00 | 50.00 | 0.00 | 5.000 | 4.980 | -0.020 |
| | 4 | 52.00 | 52.00 | 0.00 | 0.100 | 0.048 | -0.052 |

| Voltage protection threshold setting (p.u.) | Test No. | Frequency setting (Hz) | Voltage setting (p.u.) | Trip value meas. (Hz) | Trip time setting (s) | Trip time meas. (s) | Trip time deviation (s) |
|---|----------|------------------------|------------------------|-----------------------|-----------------------|---------------------|-------------------------|
| 0.21 & 1.22 | 5 | 52.00 | 0.210 | 52.00 | 5.000 | 4.980 | -0.020 |
| | 6 | 52.00 | 1.190 | 52.00 | 5.000 | 4.980 | -0.020 |
| | 7 | 52.00 | 0.190 | -- | Not protected | -- | -- |
| | | 52.00 | 0.170 | 52.00 | 5.000 | 4.960 | -0.040 |
| | 8 | 52.00 | 1.210 | -- | Not protected | -- | -- |
| | | 52.00 | 1.230 | 52.00 | 5.000 | 4.980 | -0.020 |


Test results are represented at diagrams below.




Over frequency - Test 2: Trip value




Over frequency - Test 2: Trip time




Over frequency - Test 3: Trip value




Over frequency - Test 3: Trip time




Over frequency - Test 4: Trip value



Over frequency - Test 4: Trip time




Over frequency - Test 5: Trip value



Over frequency - Test 5: Trip time




Over frequency - Test 6: Trip value



Over frequency - Test 6: Trip time




Over frequency - Test 7: Trip value




Over frequency - Test 7: Trip time



Over frequency - Test 8: Trip value



Over frequency - Test 8: Trip time



4.6.2. Means to detect island situation

The test has been performed according to the clause 4.9.4 of the standard.

This protection device is also able to detect islanded situations and disconnect the equipment from the grid. Active methods tested with a resonant circuit used for detecting islanding situations.

The compliances with these requirements are stated in the according to EN 62116. An EUT is considered to comply with the requirements for islanding protection when each case of recorded run-on time is less than 2 s or meets the requirements of local codes.

| Table: tested condition and run-on time | | | | | | | | | |
|---|---|--------------------------------------|-----------------|-----------------|------------------------|--------------------------|--------------------------|----------------------------|---|
| No. | P _{EUT} (% of EUT rating) | Reactive load (% of normal) | P _{AC} | Q _{AC} | Run-on time (ms) | P _{EUT} (KW) | Actual Q _f | V _{DC} (Vd.c.) | Which load is selected to be adjusted (R or L) |
| Test condtion A | | | | | | | | | |
| 1 | 100 | 100 | 0 | 0 | 534 | 0.76 | 1.00 | 45 | -- |
| 2 | 100 | 100 | -5 | -5 | 159 | 0.72 | 1.03 | 45 | R/L |
| 3 | 100 | 100 | -5 | 0 | 454 | 0.72 | 1.05 | 45 | R |
| 4 | 100 | 100 | -5 | +5 | 473 | 0.72 | 1.08 | 45 | R/L |
| 5 | 100 | 100 | 0 | -5 | 409 | 0.75 | 0.98 | 45 | L |
| 6 | 100 | 100 | 0 | +5 | 353 | 0.76 | 1.03 | 45 | L |
| 7 | 100 | 100 | +5 | -5 | 406 | 0.79 | 0.94 | 45 | R/L |
| 8 | 100 | 100 | +5 | 0 | 374 | 0.79 | 0.96 | 45 | R |
| 9 | 100 | 100 | +5 | +5 | 522 | 0.79 | 0.99 | 45 | R/L |
| 10 | 100 | 100 | -10 | +10 | -- | -- | -- | -- | R/L |
| 11 | 100 | 100 | -5 | +10 | -- | -- | -- | -- | R/L |
| 12 | 100 | 100 | 0 | +10 | -- | -- | -- | -- | L |
| 13 | 100 | 100 | +10 | +10 | -- | -- | -- | -- | R/L |
| 14 | 100 | 100 | +10 | +5 | -- | -- | -- | -- | R/L |
| 15 | 100 | 100 | +10 | 0 | -- | -- | -- | -- | R |
| 16 | 100 | 100 | +10 | -5 | -- | -- | -- | -- | R/L |
| 17 | 100 | 100 | +10 | -10 | -- | -- | -- | -- | R/L |
| 18 | 100 | 100 | +5 | -10 | -- | -- | -- | -- | R/L |
| 19 | 100 | 100 | +5 | 10 | -- | -- | -- | -- | R/L |
| 20 | 100 | 100 | 0 | -10 | -- | -- | -- | -- | L |
| 21 | 100 | 100 | -5 | -10 | -- | -- | -- | -- | R/L |
| 22 | 100 | 100 | -10 | -10 | -- | -- | -- | -- | R/L |
| 23 | 100 | 100 | -10 | -5 | -- | -- | -- | -- | R/L |
| 24 | 100 | 100 | -10 | 0 | -- | -- | -- | -- | R/L |
| 25 | 100 | 100 | -10 | +5 | -- | -- | -- | -- | R/L |
| Test condtion B | | | | | | | | | |
| 10 | 66 | 66 | 0 | 0 | 493 | 0.50 | 1.00 | 41 | -- |
| 11 | 66 | 66 | 0 | -5 | 451 | 0.50 | 0.98 | 41 | L |
| 12 | 66 | 66 | 0 | -4 | 466 | 0.50 | 0.99 | 41 | L |
| 13 | 66 | 66 | 0 | -3 | 517 | 0.50 | 0.99 | 41 | L |
| 14 | 66 | 66 | 0 | -2 | 450 | 0.50 | 0.99 | 41 | L |
| 15 | 66 | 66 | 0 | -1 | 446 | 0.50 | 1.00 | 41 | L |
| 16 | 66 | 66 | 0 | 1 | 458 | 0.50 | 1.01 | 41 | L |
| 17 | 66 | 66 | 0 | 2 | 502 | 0.50 | 1.03 | 41 | L |
| 18 | 66 | 66 | 0 | 3 | 299 | 0.50 | 1.03 | 41 | L |
| 19 | 66 | 66 | 0 | 4 | 427 | 0.50 | 1.04 | 41 | L |
| 20 | 66 | 66 | 0 | 5 | 126 | 0.50 | 1.04 | 41 | L |
| 21 | 66 | 66 | 0 | 6 | -- | -- | -- | -- | L |

Table: tested condition and run-on time

| No. | P _{EUT} (% of EUT rating) | Reactive load (% of normal) | P _{AC} | Q _{AC} | Run-on time (ms) | P _{EUT} (KW) | Actual Q _f | V _{DC} (Vd.c.) | Which load is selected to be adjusted (R or L) |
|------------------|------------------------------------|-----------------------------|-----------------|-----------------|------------------|-----------------------|-----------------------|-------------------------|--|
| Test condition C | | | | | | | | | |
| 22 | 33 | 33 | 0 | 0 | 492 | 0.25 | 1.00 | 35 | -- |
| 23 | 33 | 33 | 0 | -5 | 421 | 0.25 | 0.97 | 35 | L |
| 24 | 33 | 33 | 0 | -4 | 632 | 0.25 | 0.98 | 35 | L |
| 25 | 33 | 33 | 0 | -3 | 534 | 0.25 | 0.99 | 35 | L |
| 26 | 33 | 33 | 0 | -2 | 464 | 0.25 | 0.99 | 35 | L |
| 27 | 33 | 33 | 0 | -1 | 430 | 0.25 | 0.99 | 35 | L |
| 28 | 33 | 33 | 0 | 1 | 170 | 0.25 | 1.07 | 35 | L |
| 29 | 33 | 33 | 0 | 2 | 109 | 0.25 | 1.07 | 35 | L |
| 30 | 33 | 33 | 0 | 3 | 137 | 0.25 | 1.08 | 35 | L |
| 31 | 33 | 33 | 0 | 4 | 155 | 0.25 | 1.08 | 35 | L |
| 32 | 33 | 33 | 0 | 5 | 152 | 0.25 | 1.08 | 35 | L |

Remark:


For test condition A:

If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.


For test condition B and C:

If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments are taken until run-on times begin decreasing.


Test Condition A



Test Condition B



Test Condition C



4.6.3. Digital input to the interface protection

The test has been performed according to the clause 4.9.5 of the standard.

The interface protection shall have at least two configurable digital inputs, EUT used active methods tested with a resonant circuit and ROCOF to comply to the clause.

4.7. CONNECTION AND STARTING TO GENERATE ELECTRICAL POWER

The test has been performed according to the clause 4.10 of the standard.

4.7.1. Automatic reconnection after tripping

The test has been performed according to the clause 4.10.2 of the standard.

The frequency range, the voltage range, the observation time shall be adjustable in the range according to Table 3 column 2. If no settings are specified by the DSO and the responsible party, the default settings for the reconnection after tripping of the interface protection are according to Table 3 column 3.

Table 3 — Automatic reconnection after tripping

| Parameter | Range | Default setting |
|--------------------------------|----------------------------|----------------------|
| Lower frequency | 47,0Hz – 50,0Hz | 49,5Hz |
| Upper frequency | 50,0Hz – 52,0Hz | 50,2Hz |
| Lower voltage | 50% – 100%U _n | 85 % U _n |
| Upper voltage | 100% – 120% U _n | 110 % U _n |
| Observation time | 10s – 600s | 60s |
| Active power increase gradient | 6% – 3000%/min | 10%/min |

The following definitions apply to the test to verify the clause:

| Disconnection Setting | | Reconnection Setting | | Setting Reconnection time (s) | Meas. Reconnection time (s) | Setting gradient (%Pn/min) | Meas. gradient (%Pn/min) |
|-----------------------|-----|----------------------|-----|-------------------------------|-----------------------------|----------------------------|--------------------------|
| U= 115 %Un | Yes | U = 110 %Un | Yes | 60.0 | 75.6 | 6.0 | 4.88 |
| U = 84 %Un | Yes | U = 85 %Un | Yes | 10.0 | 13.4 | 10.0 | 7.79 |
| f = 52.00 Hz | Yes | f = 50.20 Hz | Yes | 600.0 | 600.9 | 3000.0 | 1332.00 ⁽¹⁾ |
| f = 47.50 Hz | Yes | f = 49.50 Hz | Yes | 100.0 | 109.8 | 10.0 | 7.64 |

⁽¹⁾ This is the maximum gradient which can be measured for the setting of 3000.0 %Pn/min.

Note: See section 4.7.2 for the test result graph.

4.7.2. Starting to generate electrical power

The test has been performed according to the clause 4.10.3 of the standard.

The frequency range, the voltage range, the observation time shall be adjustable in the range according to Table 4 column 2. If no settings are specified by the DSO and the responsible party, the default settings for connection or starting to generate electrical power due to normal operational startup or activity are according to Table 4 column 3.

Table 4 — Starting to generate electrical power


| Parameter | Range | Default setting |
|--------------------------------|-------------------|-----------------|
| Lower frequency | 47,0Hz – 50,0Hz | 49,5Hz |
| Upper frequency | 50,0Hz – 52,0Hz | 50,1Hz |
| Lower voltage | 50% – 100% U_n | 85 % U_n |
| Upper voltage | 100% – 120% U_n | 110 % U_n |
| Observation time | 10s – 600s | 60s |
| Active power increase gradient | 6% – 3000%/min | disabled |

The following definitions apply to the test to verify the clause:


| Connection | | Setting Connection time (s) | Meas. Connection time (s) | Setting gradient (%Pn/min) | Meas. gradient (%Pn/min) |
|------------------------|-----|-----------------------------|---------------------------|----------------------------|--------------------------|
| $U < 110 \% U_n$ | Yes | 60.0 | 75.4 | 6.0 | 4.86 |
| $85 \% < U$ | Yes | 10.0 | 13.6 | 10.0 | 7.79 |
| $f < 50.10 \text{ Hz}$ | Yes | 600.0 | 601.1 | 3000.0 | 1336.00 ⁽¹⁾ |
| $49.50 < f$ | Yes | 100.0 | 115.8 | 10.0 | 7.70 |

⁽¹⁾ This is the maximum gradient which can be measured for the setting of 3000.0 %Pn/min.


Test results are represented at diagrams below.



Overfrequency Connection and Reconnection



Underfrequency Connection and Reconnection



4.7.3. Synchronization

The requirements are from clause 4.10.4 of the standard. Synchronizing a generating plant/unit with the distribution network shall be fully automatic.


The EUT is fully automatic in the connection to the distribution network.

4.8. CEASING AND REDUCTION OF ACTIVE POWER ON SET POINT

4.8.1. Ceasing active power

The test has been performed according to the clause 4.11.1 of the standard.

Generating plants with a maximum capacity of 0.8 kW or more shall be equipped with a logic interface (input port) in order to cease active power output within 5 seconds following an instruction being received at the input port. If required by the DSO and the responsible party, this includes remote operation.




4.8.2. Reduction of active power on set point

Test requirements according to the clause 4.11.2 of the standard.

| Active Power step (%P _n) | Setpoint value | | Actual value | | Deviation <±5% P _n | | Gradient 0.66%P _n /s to 0.33%P _n /s (%P _n /s) |
|--------------------------------------|----------------|--------------------|--------------|--------------------|-------------------------------|--------------------|--|
| | (kW) | (%P _n) | (kW) | (%P _n) | (kW) | (%P _n) | |
| 100 | 0.800 | 100 | 0.800 | 100.0 | 0.000 | 0.0 | -- |
| 90 | 0.720 | 90 | 0.721 | 90.1 | +0.001 | +0.1 | -0.48 |
| 80 | 0.640 | 80 | 0.642 | 80.2 | +0.002 | +0.2 | -0.52 |
| 70 | 0.560 | 70 | 0.563 | 70.4 | +0.003 | +0.4 | -0.50 |
| 60 | 0.480 | 60 | 0.483 | 60.4 | +0.003 | +0.4 | -0.46 |
| 50 | 0.400 | 50 | 0.404 | 50.5 | +0.004 | +0.5 | -0.43 |
| 40 | 0.320 | 40 | 0.324 | 40.5 | +0.004 | +0.5 | -0.38 |
| 30 | 0.240 | 30 | 0.244 | 30.5 | +0.004 | +0.5 | -0.45 |
| 20 | 0.160 | 20 | 0.164 | 20.5 | +0.004 | +0.5 | -0.51 |
| 10 | 0.080 | 10 | 0.078 | 9.8 | -0.002 | -0.2 | -0.47 |
| 0 | 0.000 | 0 | 0.000 | 0.0 | 0.000 | 0.0 | -0.53 |

Test results are represented at diagrams below.



4.9. REQUIREMENTS REGARDING SINGLE FAULT TOLERANCE OF INTERFACE PROTECTION SYSTEM AND INTERFACE SWITCH

The requirements are from clause 4.3.2 and 4.13 of the standard.

1) The compliances with the requirements of clause 4.3.2 are met with the following structure:

The output is switched off redundantly by the high-power switching bridge and relays, model: HF115F/012-2HS4AF , rated: 8A/250Vac.

2) The compliances with the requirements of clause 4.13 are stated in section 4.4 and 4.4.4 of the following test report:

IEC 62109-1: 2010 and IEC 62109-2: 2011: Test Report no. GZES240100138501 and GZES240100138502, issued by SGS-SCTS Standards Technical Services Co., Ltd. Guangzhou Branch, on February 19 of 2024. GAC ATL 0032.

5. PICTURES**Front view****Back view**

Internal view




Front view of main board



Back view of main board




After gluing



Serial Number**Software Version**

DH01.001-000-000

6. ELECTRICAL SCHEME



-----End of Report-----